

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)0 1 C I A S I O S 2 2 0 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CONT

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 6 1 7 1 0 2 1 8 3 8 1 1 1 2 1 8 3 9
7 8 DOCKET NUMBER 60 61 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On 10/21/83, at 1348, with Units 2 and 3 in Mode 1, a ground fault alarm

0 3 was received on data gathering panel 2/3L-198 for Fire Zones 44 and 83.

0 4 The panel was declared inoperable, and in accordance with LCO 3.3.3.7,

0 5 Action Statement 'a', compensatory fire watches were established within

0 6 one hour. The health and safety of the public was not affected.

0 7

0 8

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
A B 11 E 12 X 13 I N S T R U 14 E 15 Z 16

17 LER/RO REPORT NUMBER 18 8 3 19 13 6 20 0 3 21 L 22 0
23 1 24 25 26 27 28 29 30 31 32

33 X 34 X 35 Z 36 Z 37 0 0 0 0 38 N 39 N 40 N 41 A 42 A 43 A 44 6 45 0 46 5 47

48 ACTION TAKEN 49 FUTURE ACTION 50 EFFECT ON PLANT 51 SHUTDOWN METHOD 52 HOURS 53 ATTACHMENT SUBMITTED 54 NPD-4 FORM SUB 55 PRIME COMP. SUPPLIER 56 COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The ground fault cleared and the system returned to service at 1715

1 1 on 10/21/83. This event is considered spurious and no further correc-

1 2 tive action is planned.

1 3

1 4

1 5 FACILITY STATUS N. POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
E 28 1 0 0 29 NA A 31 Operator Observation

1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
Z 33 Z 34 NA NA

1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 NA
0 0 0 37 Z 38

1 8 PERSONNEL INJURIES NUMBER DESCRIPTION 41 NA
0 0 0 40

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43 NA
Z 42

2 0 PUBLICITY ISSUED DESCRIPTION 45 NA
N 44

8312060120 831121
PDR ADOCK 05000361
S PDR

NAME OF PREPARER

J. G. HAYNES

PHONE

714/492-7700

NRC USE ONLY

RECEIVED
NRC

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

1983 NOV 25 AM 11:22

REGION VISE

SCE

J. G. HAYNES
STATION MANAGER

November 21, 1983

TELEPHONE
(714) 492-7700

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
30-Day Report
Licensee Event Report No. 83-136 (Docket No. 50-361)
San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to Section 6.9.1.13.b of Appendix A, Technical Specifications to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, this submittal provides the required 30-day written report and a copy of the Licensee Event Report (LER) form for an occurrence involving Limiting Condition for Operation (LCO) 3.3.3.7 associated with Fire Detection Instrumentation. Since this occurrence involves shared systems between Units 2 and 3, in accordance with NUREG-0161, a single LER for Unit 2, LER No. 83-136 (Docket No. 50-361), is enclosed.

On October 21, 1983, at 1348, with Units 2 and 3 in Mode 1 at 100% and 50% power, respectively, a ground fault alarm was received on the data gathering panel 2/3L-198 for Fire Zones 44 and 83. The panel was declared inoperable, and in accordance with LCO 3.3.3.7, Action Statement 'a', compensatory fire watches were established within one hour and were maintained until the panel was returned to service. At 1715, the same day, the ground fault cleared and the panel was returned to service. No cause could be identified to explain the ground. The event is considered spurious and no further corrective action is planned.

1/1 IE-22

November 21, 1983

If you require any additional information, please so advise.

Sincerely,

V. G. Layman

Enclosure: LER No. 83-136

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Division of Technical Information and Document Control

Institute of Nuclear Power Operations (INPO)