



Tennessee Valley Authority, Post Office Box 2000, Nashville, Tennessee 37279

Jack L. Wilson
Vice President, Sequoyah Nuclear Plant

August 28, 1991

TVA-SQN-TS-91-03

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)
Tennessee Valley Authority)

Docket Nos. 50-327
50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION (TS) CHANGE 91-03

In accordance with 10 CFR 50.90, we are enclosing a requested amendment to Licenses DPR-77 and DPR-79 to change the TSs of SQN Units 1 and 2. The proposed change will provide an increased allowed outage time of 7 days for the centrifugal charging pumps as applied to TSs for reactivity control and emergency core cooling system requirements.

TVA requests NRC review and approval of the proposed TS change. This change can be implemented without any physical modification and only minor procedure changes. Therefore, implementation can be achieved upon staff approval of this request. However, TVA requests a 30-day implementation period from receipt of the approved change to place procedure revisions in effect and distribute the revised TS pages.

The proposed TS change is identified in Enclosure 1. The justification for the proposed TS change is provided in Enclosure 2. A proposed determination of no significant hazards consideration performed pursuant to 10 CFR 50.92 is provided in Enclosure 3. Supporting documentation to this proposed TS change provided by Westinghouse Electric Corporation is included in Enclosure 4.

9109060017 910828
PDR ADOCK 05000327
P PDR

Adol
11


U.S. Nuclear Regulatory Commission

August 28, 1991

Please direct questions concerning this issue to Keith C. Weller at
(615) 843-7527.


Very truly yours,

TENNESSEE VALLEY AUTHORITY



J. L. Wilson

Sworn to and subscribed before me
this 28th day of August 1991


Notary Public
My Commission Expires 8-4-92

Enclosures

cc (Enclosures):

American Nuclear Insurers
Attention: Librarian
The Exchange, Suite 245
270 Farmington Avenue
Farmington, Connecticut 06032

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Michael H. Mobley, Director (w/o Enclosures)
Division of Radiological Health
T.E.R.R.A. Building
150 9th Avenue, N
Nashville, Tennessee 37203