

3150-0011

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE

714/492-7700

RECEIVED
NRC

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

NOV 23 AM 11:23

REGION V

SCE

J. G. HAYNES
STATION MANAGER

November 21, 1983

TELEPHONE
(714) 492-7700

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
30-Day Report
Licensee Event Report No. 83-138
San Onofre Nuclear Generating Station, Unit 2

Pursuant to Section 6.9.1.13.b of Appendix A, Technical Specifications to Facility Operating License NPF-10 for San Onofre Unit 2, this submittal provides the required 30-day written report and a copy of the Licensee Event Report (LER) form for an occurrence involving Limiting Condition for Operation (LCO) 3.6.3 associated with the Containment Isolation Valves.

On October 21, 1983, at 0145 with Unit 2 in Mode 1 at 100% power, Containment Isolation Valve 2HV7258 failed to close during the Waste Gas Quarterly Valve Test required by Surveillance Requirement 4.6.3. 2HV7258 was declared inoperable and in accordance with LCO 3.6.3, Action Statement 'b', 2HV7259 was secured in the isolation position within four hours at 0210.

The inoperability of 2HV7258 was due to a loose connection on the terminal block for the closing circuit. The connection was tightened and on October 24, 1983, at 1400, 2HV7258 was declared operable in accordance with Procedure S023-3-3.30.


This is considered an isolated occurrence and no further action is planned. There was no impact on the health and safety of plant personnel or the public associated with this event.

11
IE-22

November 21, 1983

If you require any additional information, please so advise.

Sincerely,



Enclosure: LER 83-138

cc: A.E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)
J.P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U.S. Nuclear Regulatory Commission
Division of Technical Information and Document Control

Institute of Nuclear Power Operations (INPO)