



Duquesne Light

Nuclear Division
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

November 22, 1983

United States Nuclear Regulatory Commission
Director of Nuclear Reactor Regulation
Attn: Mr. Steven A. Varga
Operating Reactors Branch No. 1
Division of Licensing
Washington, DC 20555


Reference: Beaver Valley Power Station Unit No. 1
Docket No. 50-334, License No. DPR-66
Reactor Containment Building
Integrated Leak Rate Test Report

Gentlemen:

Enclosed is the 1983 Reactor Containment Building Integrated Leak Rate Test report, submitted in accordance with 10 CFR 50 Appendix J. This report provides a technical summary of the BVPS-1 Type B and C tests completed during the months of August and September of the 1983 refueling outage.

The test results justify our conclusion that since the combined leakage rate of all penetrations and valves subject to type B and C testing is below the Technical Specification limit of 0.6 La, that containment penetration leakage is acceptable.

Very truly yours,


J. J. Carey
Vice President, Nuclear

Attachment

cc: Mr. W. M. Troskoski, Resident Inspector
U. S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

U. S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, DC 20555

Director, Safety Evaluation & Control
Virginia Electric & Power Company
P. O. Box 26666
One James River Plaza
Richmond, Virginia 23261

8312080039 831122
PDR ADOCK 05000334
PDR

Ad 17
11