

*Southern California Edison Company*



SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES  
STATION MANAGER

TELEPHONE  
(714) 492-7700

November 28, 1983

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Reference: Letter, J. G. Haynes (SCE) to J. B. Martin (NRC)  
dated November 14, 1983

Subject: Docket Nos. 50-361 and 50-362  
Cancellation of Licensee Event Report No. 83-143  
(Docket No. 50-361)  
San Onofre Nuclear Generating Station, Units 2 and 3

The referenced letter provided the written confirmation of our prompt notification pursuant to Section 6.9.1.12.b of Appendix A, Technical Specifications to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, of an occurrence involving the onsite power distribution system.

The referenced letter indicated that Limiting Condition for Operation (LCO) 3.0.3 had been entered for approximately 12 minutes beginning at 1430 on November 11, 1983, as a result of considering Emergency Chiller E-336 inoperable. The conclusion that E-336 was inoperable was based on the belief that component cooling water, which was being provided by Unit 3 Train A Component Cooling Water (CCW) pump 3P-024, had been interrupted while preparing Unit 3 CCW swing pump 3P-025 for post maintenance testing. Further review of this matter confirmed that Unit 3 Train A CCW pump 3P-024 operation was not interrupted and, in the event of loss of offsite power, 3P-024 would have been automatically restarted. Therefore, Emergency Chiller E-336 remained operable and no entry into LCO 3.0.3 was made.

Consequently, Licensee Event Report (LER) No. 83-143 (Docket No. 50-361), originally assigned to this event, will be reassigned to a future report.

8312090088 831128  
PDR ADOCK 05000361  
S PDR

1/0 IE-22

Mr. J. B. Martin

-2-

November 28, 1983

If there are any questions regarding the above, please contact me.

Sincerely,

*VG Haynes*

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)  
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)