

THE CINCINNATI GAS & ELECTRIC COMPANY



November 29, 1983
LOZ-83-0230

J. WILLIAMS, JR.
SENIOR VICE PRESIDENT
NUCLEAR OPERATIONS

Docket No. 50-358

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J.G. Keppler
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
10CFR50.55(e), ITEM M-96, INDETERMINATE
QUALIFICATION OF SUPPLIER PER ASME SECTION III
W.O. 57300, JOB E-5590, FILE NO. 956C, M-96

This letter constitutes an interim report concerning the subject condition reported to the Commission on September 2, 1983, as a potentially reportable deficiency under 10CFR50.55(e). Our last report, LOZ-83-0167, was submitted on September 30, 1983.

The audit of Cooperheat by H.J. Kaiser Company has been completed. The results of this audit have determined that Cooperheat implemented a quality assurance program in September 1982. All purchase orders issued to Cooperheat were dated prior to September, 1982.

H.J. Kaiser's Quality Assurance Department is in the process of performing an evaluation of the purchase orders to determine the acceptability of items procured from Cooperheat. A report detailing the results of this evaluation and any identified corrective action will be submitted by June 1, 1984.

8312090129 831127
PDR ADOCK 05000358
S PDR

DEC -2 1983


1/0 T827

Mr. J.G. Keppler
Regional Administrator
November 29, 1983
LOZ-83-0230
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By 
J.C. WILLIAMS, JR.
SENIOR VICE PRESIDENT

DJS/sfr

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Resident Site Supervisor
ATTN: W.M. Hill
NRC Zimmer Project Inspector, Region III
ATTN: E. R. Schweibinz