



**Consumers
Power
Company**

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0774

November 22, 1983

Mr J J Harrison
Midland Project Section
U S Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND ENERGY CENTER GWO 7020

WORK AUTHORIZATION PROCEDURE

FILE: 048516

UFI: 42*05*22*04,12*32

SERIAL: CSC-7027

This letter documents the November 16, 1983 phone conversation between R. Wheeler of CPCo and Dr. R. Landsman of NRC Region III. As part of the work package for Activities 165054045 and 155054045 (Piers CT1 & CT12), Dr. Landsman reviewed the soil stabilization grouting plan for the control tower area. Therefore, CPCo may proceed with the soil stabilization as required for both piers CT1/12 and the remainder of the control tower. The sequencing of this grouting will be done for the convenience of construction, but at no time will drifts in this area proceed in unstabilized soil that has not been approved by the RGE. Actual pier and drift excavations for piers beyond CT1/12 will be authorized by Region III in accordance with the Work Authorization Procedure. Dr. Landsman concurred with the authorization of the soil stabilization under the previously authorized activities.

JAMooney

JAM/RHW/pl

Mooney
Executive Manager
Midland Project Office

PRINCIPAL STAFF			
✓ RA	<i>Lee</i>	DPRP	
D/RA		DE	
A/RA		DRMSP	
✓ RC	<i>Don</i>	DRMA	
PAO		SCS	<i>ing + 3</i>
SGA		ML	
File		File	<i>Lee</i>

8312090182 831122
PDR ADOCK 05000329
A PDR

110 IED/
DEC 5 1983