

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

November 28, 1983
ANPP-28290-BSK/KCP

U. S. Nuclear Regulatory Commission
Region V
Creskide Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs

Subject: Interim Report - DER 83-73
A 50.55(e) Potentially Reportable Deficiency Relating to
Unqualified Foxboro Power Supplies were Installed in IE
Instrumentation Cabinets
File: 83-019-026; D.4.33.2


Reference: Telephone Conversation between P. Narbut and R. Tucker on
October 27, 1983

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the
referenced telephone conversation. At that time, it was estimated that a
determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an Interim
Report is attached. It is now expected that this information will be
finalized by January 5, 1984, at which time a complete report will be
submitted.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President,
Nuclear Projects Management
ANPP Project Director

EEVB/KCP:sls
Attachment

cc: See Page Two

54-528

8312120226 831128
PDR ADOCK 05000528
S PDR

11
IE-27

Mr. T. W. Bishop
DER 83-73
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
G. C. Andognini
J. A. Roedel
D. B. Fasnacht
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. R. Bynum
D. D. Green
P. P. Klute
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli
S. R. Frost
J. Self
D. Canady

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339

INTERIM REPORT - DER 83-73
POTENTIAL REPORTABLE DEFICIENCY
ARIZONA PUBLIC SERVICE COMPANY (APS)
PVNGS UNIT 1

I. POTENTIAL PROBLEM

Unqualified Foxboro power supplies have been installed in the following QIE instrumentation cabinets:

<u>Plant Tag Number</u>	<u>Description</u>	<u>PO Specification</u>
1JSFNC03F	NSSS Control Systems Cabinet	NM-001
2JSBDC02A	Process Protective Cabinet A1	NM-001
2JSBBC02A	Process Protective Cabinet B1	NM-001
2JSCCC02A	Process Protective Cabinet C1	NM-001

II. APPROACH TO AND STATUS OF PROPOSED RESOLUTION

Bechtel Engineering is evaluating the reportability and technical justification for corrective action.

III. PROJECTED COMPLETION OF CORRECTIVE ACTION AND SUBMITTAL OF THE FINAL REPORT

Evaluation of this condition and submittal of the Final Report is forecast to be completed by January 5, 1984.