

3150-0011

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE: 714/492-7700

RECEIVED  
NRG

1983 DEC -5 PM 2 Southern California Edison Company

SCE

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES  
STATION MANAGER

REGION V

TELEPHONE  
(714) 492-7700

December 2, 1983

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket No. 50-362  
30-Day Report  
Licensee Event Report No. 83-101  
San Onofre Nuclear Generating Station, Unit 3

Pursuant to Section 6.9.1.13.b of Appendix A, Technical Specifications to Facility Operating License NPF-15 for San Onofre Unit 3, this submittal provides the required 30-day written report and a copy of the Licensee Event Report (LER) form for an occurrence involving Limiting Condition for Operation (LCO) 3.3.1 associated with the Reactor Protection System (RPS).

On November 11, 1983, at 0520, with Unit 3 in Mode 1 at 80% power, during performance of a shiftly surveillance, operators observed that Core Protection Calculator (CPC) Channel B had experienced more than three auto-restarts in the previous 12-hour period. Pursuant to LCO 3.3.1, Table 3.3-1, Action Statement 7, CPC Channel B operability was demonstrated within 24 hours by the completion of a Channel Functional Test at 1100 on November 11, 1983. No cause for the auto-restarts was found and no further corrective action is planned. There was no impact on the health and safety of plant personnel or the public associated with this event.

11  
IE-22


Mr. J. B. Martin

-2-

December 2, 1983

If you require any additional information, please so advise.

Sincerely,



Enclosure: LER No. 83-101

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)  
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission  
Division of Technical Information and Document Control

Institute of Nuclear Power Operations (INPO)