

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE (805) 595-7351

8312120339 831202  
PDR ADOCK 05000275  
S PDR

IE22

PACIFIC GAS AND ELECTRIC  
DIABLO CANYON POWER PLANT  
UNIT 1 DOCKET NO. 50-275  
LICENSEE EVENT REPORT 83-028/01T-0

SUPPLEMENTAL INFORMATION

As this was Unit 1's initial fuel load, all Core Alterations while in Mode 6 involved the movement of non-irradiated fuel elements. Any damage would not have resulted in the release of radioactive materials from containment to the environment.

No Core Alterations are being performed in Unit 1 at this time, so the equipment hatch is not now required to be closed.

# PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER  
MANAGER

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
NUCLEAR POWER GENERATION

December 2, 1983

Mr. John B. Martin, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, CA 94596-5368


Re: Docket No. 50-275, OL-DPR-76  
Diablo Canyon Unit 1  
Licensee Event Report 83-028/01T-0  
Containment Equipment Hatch

Dear Mr. Martin:

Pursuant to Section 6.9.1.12c of the Technical Specifications, Appendix A to the Diablo Canyon Unit 1 Operating License, the enclosed Licensee Event Report is submitted concerning an air gap between the sealing surfaces of the containment equipment hatch during initial fuel loading.

This event has in no way affected the public's health and safety.

Sincerely,



Enclosure

cc: G. W. Knighton

Director, Office of Management Information  
and Program Control

Service List

REGIONAL V

1983 DEC -6 AM 10:56

RECEIVED  
HPC

11  
IE-22