



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

DEC 7 82:27
December 2, 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-106/0 -
Smoke Detectors Covered to
Support Planned Maintenance
Activities
AECM-83/0771

On October 21 and October 26, 1983, smoke detectors N515-N, N515-0 in Zone 1-15, and smoke detectors N523-S, N523-R in Zone 1-23 were covered to support planned maintenance activities (painting). Fire watches were established in accordance with Technical Specification 3.7.7 until the detectors were restored on November 9, 1983.

This is submitted as a Special Report pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation (LCO) was exceeded. The event had no effect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

L. F. Dale

for L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap

cc: (See Next Page)

8312130262 831202
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

1222

1/0

MISSISSIPPI POWER & LIGHT COMPANY

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555