

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)01 | S | C | V | C | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 0 | 0 | 0 | 4 | 5 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33CONT
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 9 | 5 | 7 | 1 | 1 | 0 | 3 | 8 | 3 | 8 | 1 | 2 | 0 | 2 | 8 | 3 | 9 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On November 3, 1983, with the Plant in Mode 1, a discrepancy of 10% was observed

03 | during the performance of a Channel Check between the Main Control Board and the

04 | Control Room Evacuation Panel (CREP) indication for Pressurizer Relief Tank

05 | Level. There were no adverse consequences resulting from this event which is

06 | similar to a previous failure identified in LER 83-118. Transmitter LT-470A was

07 | calibrated and returned to operable status on 11/3/83 in accordance with Action

08 | Statement (a) of Technical Specification 3.3.3.5.

09 | SYSTEM CODE | I | D | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | X | 13 | COMPONENT CODE | I | N | S | T | R | U | 14 | COMP. SUBCODE | T | 15 | VALVE SUBCODE | Z | 16 |

17 | LER/RO REPORT NUMBER | 8 | 3 | 21 | EVENT YEAR | 8 | 3 | 22 | SEQUENTIAL REPORT NO. | 1 | 2 | 7 | 23 | OCCURRENCE CODE | 0 | 3 | 24 | REPORT TYPE | L | 25 | REVISION NO. | 0 | 26 |

18 | ACTION TAKEN | E | 18 | FUTURE ACTION | X | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 22 | ATTACHMENT SUBMITTED | N | 23 | NPRD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | A | 25 | COMPONENT MANUFACTURER | R | 3 | 6 | 9 | 26 |

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The discrepancy observed on 11/3/83 was due to a zero shift on transmitter

11 | LT-470A which provides the CREP indication. An engineering evaluation of the

12 | recurring drift problem and any corrective action required to increase the

13 | reliability of LT-470A will be completed by the end of the next maintenance

14 | outage, presently scheduled to begin in April 1984.

15 | FACILITY STATUS | E | 28 | % POWER | 1 | 0 | 0 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Surveillance Test | 32 |

16 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36 |

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39 |

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41 |

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | N/A | 43 |

20 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | N/A | 45 |

NAME OF PREPARER

C. J. McKinney
C. J. McKinney

PHONE: (803) 345-5209

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE 764

COLUMBIA, SOUTH CAROLINA 29218

O. W. DIXON, JR.
VICE PRESIDENT
NUCLEAR OPERATIONS

DEC 7 P2:27
December 2, 2, 1983

Mr. James P. O'Reilly
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II, Suite 2900
101 Marietta Street, N.W.
Atlanta, Georgia 30303


SUBJECT: Virgil C. Summer Nuclear Station
Docket No. 50/395
Operating License No. NPF-12
Thirty Day Written Report
LER 83-127

Dear Mr. O'Reilly:

Please find attached Licensee Event Report #83-127 for the Virgil C. Summer Nuclear Station. This Thirty Day Report is required by Technical Specification 6.9.1.13.(b) as a result of entry into Action Statement (a) of Technical Specification 3.3.3.5, "Remote Shutdown Instrumentation," on November 3, 1983.

Should there be any questions, please call us at your convenience.

Very truly yours,



O. W. Dixon, Jr.

CJM:OWD/mac
Attachment

cc: V. C. Summer
T. C. Nichols, Jr./O. W. Dixon, Jr.
E. H. Crews, Jr.
E. C. Roberts
W. A. Williams, Jr.
D. A. Nauman
Group Managers
O. S. Bradham
C. A. Price
J. F. Heilman
D. A. Lavigne

C. L. Ligon (NSRC)
G. J. Braddick
D. J. Richards
NRC Res. Inspector
J. B. Knotts, Jr.
I&E (Washington)
Document Management
Branch
INPO Records Center
NPCF
File

OFFICIAL COPY

1122
1/1