



Duquesne Light

Nuclear Division
P.O. Box 4
Shippingport, PA 15077-0004

Telephone (412) 393-6000

December 7, 1983

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Division of Licensing
Attn: D. G. Eisenhut, Director
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Generic Letter 83-37 Response

Gentlemen:

We have reviewed Generic Letter 83-37 and have determined that the following revisions to the Beaver Valley Power Station, Unit No. 1 Technical Specifications are applicable:

- 1) Revise Specification 3.3.3.7, Chlorine Detection Systems, to require two operable detectors.
- 2) Revise Table 3.3-11 and 4.3-7, Accident Monitoring Instrumentation, to include the following instruments:
 - a) Containment Wide Range Pressure
 - b) Containment Wide Range Water Level
- 3) Incorporate a new Administrative Controls Section 6.8.4, to require a Post-accident Sampling Program be established, implemented and maintained.
- 4) Revise Specification 3.6.4.1, Hydrogen Analyzers, for applicability to the wide range instruments.

We will forward the above changes in a request for Technical Specification change following OSC and ORC review.

The generic letter also recommends that we submit a request for Technical Specification change to incorporate the Reactor Coolant Gaseous Vent System (RCGVS) Specification within 30 days. We requested (letter dated August 25, 1983) and we understand that the NRC is presently in the process of granting an eighteen month scheduler exemption to allow


8312130305 831207
PDR ADDCK 05000334
P PDR

A001
1/0

Beaver Valley Power Station, Unit No. 1
Docket No. 5C-334, License No. DPR-66
Generic Letter 83-37 Response
Page Two

an extension of the previous deadline for operability of the RCGVS. Since the RCGVS will not be required until the end of the eighteen month exemption period we will delay submittal of the proposed Technical Specification change until operation of the system has been evaluated and corrected. This is currently scheduled for completion during the fourth refueling outage.

Very truly yours,


J. J. Carey
Vice President, Nuclear

cc: W. M. Troskoski, Resident Inspector
U. S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

U. S. Nuclear Regulatory Commission
C/O Document Management Branch
Washington, DC 20555

Director, Safety Evaluation and Control
Virginia Electric and Power Co.
P. O. Box 26666
One James River Plaza
Richmond, VA 23261