

BEFORE THE
UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of :
PHILADELPHIA ELECTRIC COMPANY : Docket Nos. 50-277
50-278

AMENDMENT TO

MARCH 24, 1981
DECEMBER 13, 1982

AUGUST 6, 1981
JUNE 22, 1983

APPLICATION FOR AMENDMENT
OF
FACILITY OPERATING LICENSES
DPR-44 & DPR-56

Edward G. Bauer, Jr.
Eugene J. Bradley

2301 Market Street
Philadelphia, Pennsylvania 19101

Attorneys for
Philadelphia Electric Company

8312140132 831205
PDR ADOCK 05000277
P PDR

BEFORE THE
UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of	:	
	:	Docket Nos. 50-277
PHILADELPHIA ELECTRIC COMPANY	:	50-278

AMENDMENT TO
MARCH 24, 1981, AUGUST 6, 1981, AND DECEMBER 13, 1982
APPLICATION FOR AMENDMENT
OF
FACILITY OPERATING LICENSES
DPR-44 & DPR-56

On March 24, 1981, Philadelphia Electric Company, Licensee under Facility Operating Licenses DPR-44 and DPR-56 for Peach Bottom Units 2 and 3, filed an Application for Amendment of the Licenses which requested that Table 3.11.D.1, titled "Safety Related Shock Suppressors", of the Technical Specifications contained in Appendix A of the Operating Licenses be amended to conform with the Standard Technical Specifications as required by

Mr. D. G. Eisenhower's letter dated November 20, 1980.

Subsequently, licensee revised its application of March 24, 1981, by Amendments dated August 6, 1981, December 13, 1982, and June 22, 1983 to reflect shock suppressor modifications.

Licensee, as a part of the modifications to be performed during the Unit 2 refueling outage scheduled for the Spring of 1984, proposes to install additional shock suppressors on the Core Spray system and the High Pressure Coolant Injection (HPCI) system piping to bring the pipe support design into conformance with the requirements of NUREG-0661, Safety Evaluation Report, Mark I Containment, Long Term Program. The modification involves the installation of two new mechanical snubbers, 14-MO-S-26 to the Core Spray system piping and 23-HB-S-110 to the HPCI system piping.

Accordingly, the Licensee hereby amends its application of March 24, 1981, by revising page 234a of Table 3.11.D.1 for Unit 2 to include snubber 23-HB-S-110 and by revising page 234o of Table 3.11.D.1 for Unit 2 to include snubber 14-MO-S-26.

Additionally, Licensee proposes to replace three hydraulic shock suppressors with new, high capacity, mechanical shock suppressors to bring the pipe support design into conformance with the requirements of NUREG-0661. The modification involves the replacement of hydraulic snubbers 10-HB-S-1 and 10-HB-S-8 in the Residual Heat Removal (RHR) system and hydraulic snubber 23-HB-S-16 in the HPCI system with new

mechanical snubbers. The new mechanical snubbers will retain the same numerical designations of the old hydraulic snubbers.

Accordingly, the Licensee hereby amends its application of March 24, 1981, as amended December 13, 1982, by changing the letter designation under the "TYPE" column on pages 234m and 234p of Table 3.11.D.1 for Unit 2 from the letter "H" for hydraulic to the letter "M" for mechanical to reflect the replacement of the hydraulic snubbers with mechanical snubbers. The proposed revision to change the number designations under the "Elevation" column of Table 3.11.D.1 for Unit 2 from "93" to "95" on page 234m and from "103" to "101" on page 234p reflects the change in the elevation of snubbers 10-HB-S-1, 10-HB-S-8, and 23-HB-S-16 as a result of implementing the modification associated with complying with NUREG-0661.

Furthermore, Licensee proposes to replace hydraulic snubber 10-HB-S-2 with a rigid restraint to bring the pipe support design into conformance with the requirements of NUREG-0661. As part of the Mark I torus improvement modifications, all of the piping attached to the torus was re-analyzed for thermal, weight, seismic and hydrodynamic loading. Replacement of snubber 10-HB-S-2 with a structural steel guide was included in the analysis and found to be acceptable according to the criteria specified in NUREG-0661.

Accordingly, the Licensee hereby proposes to delete hydraulic snubber 10-H3-S-2 from page 234m of Table 3.11.D.1 for Unit 2 as amended on March 24, 1981, and December 13, 1982.

Amendment Application dated March 24, 1981, revised the surveillance requirements for shock suppressors to conform with the Standard Technical Specifications as contained in NUREG-0123, Rev. 3, and as required by Mr. D. G. Eisenhower's letter dated November 20, 1980. In the application, several surveillance requirements were added in between Sections 4.11.D.4.a and 4.11.D.4.b of the requirements as they presently exist. As a result, the number designations of the sections of surveillance requirements were changed in the amendment application to allow for the inclusion of the additional requirements, e.g. 4.11.D.4.b was changed to 4.11.D.4.d. Likewise, the section of the surveillance requirements referenced under the "High Radiation Area During Shutdown" column of Table 3.11.D.1 for Unit 2 was also changed from 4.11.D.4.b to 4.11.D.4.d in the amendment application to coincide with the changes made to the number designation of the surveillance requirements and to continue to reference the proper surveillance requirements. However, in subsequent amendments to the March 24, 1981 amendment application, a typographical error was made in that the section referenced under the "High Radiation Area During Shutdown" column of Table 3.11.D.1 for Unit 2 refers to Section 4.11.D.4.b of the surveillance requirements, which is the surveillance requirement as it exists in the present Technical Specifications, rather than

Section 4.11.D.4.d of the surveillance requirement as proposed in the March 24, 1981 amendment application.

Accordingly, the Licensee hereby proposes to change the number designation of the section referenced under the "High Radiation Area During Shutdown" column on pages 234m and 234o of Table 3.11.D.1 for Unit 2 from 4.11.D.4.b to 4.11.D.4.d to coincide with the proper surveillance requirement as put forth in amendment application dated March 24, 1981.

The proposed changes to the Technical Specifications discussed in this amendment application and as shown on revised pages 234m, 234o, 234p, and 234q of Table 3.11.D.1 for Unit 2 reflect modifications to be performed during the Unit 2 Refueling Outage scheduled for the Spring of 1984. Therefore, the Licensee hereby requests that these changes to Table 3.11.D.1 become effective following completion of the modifications. In accordance with 10CFR50.59, Licensee hereby requests amendment issuance to accommodate making the modifications during the Refueling Outage scheduled for February, 1984.


The proposed revisions to the Technical Specification described herein reflect plant modifications required to conform with the acceptance criteria contained in Appendix A to NUREG-0661, and with the Commission's Order for Modification of License and Grant of Extension of Exemption for Peach Bottom Unit 2, issued on January 13, 1981, and amended January 19, 1982. Since the proposed revisions reflect modifications that reduce the

probability of failure in the torus attached piping systems, this amendment does not constitute a significant hazards consideration.

The Plant Operation Review Committee and the Nuclear Review Board (off-site safety review committee) have reviewed these proposed changes to the Technical Specifications, and have concluded that they do not involve an unreviewed safety question or a significant hazard consideration, and will not endanger the health and safety of the public.

Respectfully submitted,
PHILADELPHIA ELECTRIC COMPANY

By


Vice President

COMMONWEALTH OF PENNSYLVANIA

:

:

SS.

COUNTY OF PHILADELPHIA


:

S. L. Daltroff, being first duly sworn, deposes and says:

That he is Vice President of Philadelphia Electric Company, the Applicant herein; that he has read the foregoing Application for Amendment of Facility Operating Licenses and knows the contents thereof; and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.



Subscribed and sworn to
before me this 1st day
of DECEMBER, 1983




Notary Public

JUDITH Y. FRANKLIN
Notary Public, Phila., Phila. Co.
My Commission Expires July 28, 1987

CERTIFICATE OF SERVICE

I hereby certify that service of the foregoing Amendment was made upon the Commonwealth of Pennsylvania, by mailing a copy thereof, via first-class mail, to Thomas R. Gerusky, Director, Bureau of Radiological Protection, P.O. Box 2063, Harrisburg, Pennsylvania, 17120; all this 5th day of December, 1983.

A handwritten signature in cursive script, appearing to read "Eugene J. Bradley", is written over a horizontal line.

Eugene J. Bradley

Attorney for
Philadelphia Electric Company