

OPERATING DATA REPORT

DOCKET NO 50-255
 DATE 12-7-83
 COMPLETED BY AFDienes
 TELEPHONE (616)764-8913

OPERATING STATUS

Notes _____

1. Unit Name: Palisades
2. Reporting Period: 831101-831130
3. Licensed Thermal Power (MW): 2530
4. Nameplate Rating (Gross MWe): 811.7
5. Design Electrical Rating (Net MWe): 805
6. Maximum Dependable Capacity (Gross MWe): *675
7. Maximum Dependable Capacity (Net MWe): *635
8. If Changes Occur in Capacity Ratings (Items Number 3 through 7) since last report, give reasons: _____
9. Power Level to Which Restricted, if any (Net MWe): _____
10. Reasons for Restrictions, if any: _____

	This Month	Yr-to-Date	Cumulative
11. Hours In Reporting Period	<u>720</u>	<u>8016</u>	<u>104,751</u>
12. Number of Hours Reactor Was Critical	<u>0</u>	<u>5336.7</u>	<u>59,259.7</u>
13. Reactor Reserve Shutdown Hours	<u>-</u>	<u>-</u>	<u>-</u>
14. Hours Generator On-Line	<u>0</u>	<u>5283.6</u>	<u>56,278.5</u>
15. Unit Reserve Shutdown Hours	<u>-</u>	<u>-</u>	<u>-</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>12,723,432</u>	<u>115,360,224</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>3,980,520</u>	<u>35,750,440</u>
18. Net Electrical Energy Generated (MWH)	<u>0</u>	<u>3,769,958</u>	<u>33,628,014</u>
19. Unit Service Factor	<u>0</u>	<u>65.9</u>	<u>53.7</u>
20. Unit Availability Factor	<u>0</u>	<u>65.9</u>	<u>53.7</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0</u>	<u>74.1</u>	<u>50.6</u>
22. Unit Capacity Factor (Using DER Net)	<u>0</u>	<u>58.4</u>	<u>39.9</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>1.7</u>	<u>32.4</u>
24. Shutdowns Scheduled Over Next Six Months (Type, Date and Duration of Each):	_____		

25. If Shut Down at End of Report Period, Estimated Date of Start Up: 4/1/84
26. Units in Test Status (Prior to Commercial Operation): Forecast Achieved

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

*Based on condenser backpressure.

MI1083-0092A-TC03

8312150110 831130
 PDR ADOC: J5000255
 R PDR

IEQY
 111

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO 50-255
UNIT Palisades
DATE 12/07/83
COMPLETED BY AFDienes
TELEPHONE (616)764-8913

MONTH NOVEMBER 1983

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>-</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

MI1083-0091A-TC03

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-25UNIT NAME PalisadesDATE 12/8/83COMPLETED BY AFDienesTELEPHONE (616) 764-8913REPORT MONTH November

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
6	830812	S	720	C	1	-	-	-	

1 ¹
 F: Forced
 S: Scheduled

2 ²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3 ³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4 ⁴
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

5 ⁵
 Exhibit I - Same Source

(9/77)

SUMMARY OF OPERATING EXPERIENCE FOR NOVEMBER 1983

The Plant remained shutdown for refueling.



Consumers
Power
Company

Palisades Nuclear Plant: Route 2, Box 154, Covert, MI 49043

December 7, 1983

US Nuclear Regulatory Commission
Mail and Records Section
Washington, DC 20555

LICENSE REPORT OF MONTHLY OPERATING DATA
DPR-20, DOCKET NO 50-255

Enclosed is a copy of the Monthly Operating Data and a Summary of Operating Experience for the Palisades Nuclear Plant for the month of November 1983.

Dewey VanDerBerg

Dewey VanDerBerg
Acting Reactor Engineer

CC: DMKennedy, Palisades
JGKeppler, USNRC
JRSchepers, P24-314
DJVandeWalle, P24-614B
RMKrich, Palisades
Resident Inspector, Palisades
DLHackett, P11-228B
LTPhillips, P21-319
GWBruckmann, Div of Radiological Health Services, Lansing, Michigan
SMierzwa, Michigan Dept of Labor
RCallen, Michigan Public Service Commission
KMFarr, Palisades
Records Center, INPO, Atlanta, GA
PSepecenko, CE, Palisades
JBToskey, P25-101
RLRosenfeld, P26-204A
Document Control, 950*22*35*10/L
DV:83*074