

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

December 12, 1983

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

Mr. J. B. Stolz, Chief
Operating Branch No. 4
Division of Licensing
US Nuclear Regulatory Commission
Washington, DC 20555

Docket Nos. 50-277
50-278

Subject: Peach Bottom Atomic Power Station, Units 2 & 3
Mark I Program - Torus Attached Piping

File: GOVT 1-1 (NRC)

Dear Mr. Stolz:

This letter confirms the meeting that was held in our offices on September 23, 1983 and attended by Philadelphia Electric, Bechtel, NRC, and Franklin Research Center personnel (see Attachment I).

At the meeting, Philadelphia Electric and Bechtel presented information regarding the torus attached piping at Peach Bottom which completes the Mark I activities for Peach Bottom. The specific items discussed at the meeting were the following:

1. Scope of analyses and the components evaluated
2. Loading Combinations
3. Analysis Methods
4. Acceptance Criteria
5. Conclusions
6. Modifications Required

All modifications for Unit 3 have been completed. The only Unit 3 activities remaining are the completion of equipment nozzle evaluations and as-built reconciliation of the modifications. Work on Unit 2 modifications is in progress and will be completed by the end of the next refueling outage (currently scheduled to start February 20, 1984).

A preliminary copy of the addendum to the Plant Unique Analysis Report covering the torus attached piping has been informally transmitted to your Mr. H. Shaw. The final report will be transmitted after the Unit 2 modifications are completed. Submittal of the final report is tentatively scheduled for June, 1984.

At the conclusion of the meeting, your Mr. H. Shaw summarized the NRC's position as follows:

8312150189 831212
PDR ADOCK 05000277
P PDR

A001
11

1. All the NRC's questions regarding the Mark I program and torus attached piping had been answered.
2. It is recognized that the final report would be submitted after all modifications and evaluations are completed.
3. The preliminary results regarding torus attached piping are acceptable.

We understand that these comments will enable the NRC to complete this portion of the Mark I program.

Sincerely,

John S. Kump

Copy to: H. Shaw, NRC

ATTACHMENT I

Attendance List for September 23, 1983 Meeting

<u>Name</u>	<u>Organization</u>
D. W. Baldwin	Philadelphia Electric Co.
D. M. O'Rourke	Philadelphia Electric Co.
J. F. O'Rourke	Philadelphia Electric Co.
H. W. Vollmer	Philadelphia Electric Co.
M. Khlafaliah	Bechtel Power Corp.
R. Palaniswamy	Bechtel Power Corp.
H. Shaw	U.S. Nuclear Regulatory Commission
A. K. Le	Franklin Research Center
N. Subramonian	Franklin Research Center
S. Triole	Franklin Research Center