


Georgia Power Company
333 Piedmont
Atlanta, Georgia 30308
Telephone 404 526-7726

Mailing Address
Post Office Box 4545
Atlanta, Georgia 30302

D. O. Foster
Vice President and General Manager
Vogtle Project

USNRC REGION 3
ATLANTA, GEORGIA 30303

83 DEC 12 A 9: 37


Georgia Power
the southern electric system

November 3, 1983

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II-Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

File: X7BG03-M48
Log: GN-275

Reference: Vogtle Electric Generating Plant - Units 1 and 2
50-424, 50-425; Westinghouse-NLP Printed Circuit Cards

Attention: Mr. James P. O'Reilly


Gentlemen:

On October 4, 1983, Mr. C. W. Hayes identified a potential deficiency to Mr. J. Rogge concerning the possibility of heat sinks becoming detached from the back of Westinghouse NLP printed circuit cards. Since these sinks are metallic, the possibility exists that some circuits could be shorted out. At this time, Georgia Power Company is conducting a review to determine which, if any, cabinets contain these printed circuit cards. Georgia Power Company also intends to conduct an engineering review to ensure possible system interaction effects are also reviewed.

Based upon the completion schedule proposed by the architect/engineer, Georgia Power Company expects to submit a final report to the NRC on this concern by December 21, 1983.

This response contains no proprietary information and may be placed in the NRC Public Document Room upon receipt.

Yours truly,


D. O. Foster

8312160185 831103
PDR ADOCK 05000424
S PDR

DOF/REF/cc

xc: U. S. Regulatory Commission
Document Control Desk
Washington, D. C. 20555

OFFICIAL COPY

xc: R. J. Kelly
R. E. Conway
G. F. Head
J. T. Beckham, Jr.
D. N. MacLemore
D. E. Dutton
W. F. Sanders

R. H. Pinson
B. M. Guthrie
R. A. Thomas
J. A. Bailey
O. Batum
H. H. Gregory, III
C. W. Hayes

E. D. Groover
L. T. Gucwa
M. Malcolm
G. Bockhold
P. D. Rice
J. L. Vota

110