



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

DEC 16 1983
December 12, 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-109/0 - Fire
Barriers Opened to
Implement a Design Change
Package
AECM-83/0789

On November 5, 1983, fire barriers located in Control Room floor panel 1H13-U735, LA53-L091 were opened to implement a design change package. A fire watch was established in accordance with Technical Specification 3.7.7 until the barriers were resealed on December 4, 1983. This condition had no effect on the health and safety of the public and did not constitute a threat to plant safety. This Special Report is submitted pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation time limit was exceeded.

Yours truly,

L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

8312200081 831212
PDR ADOCK 05000416
S PDR

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

1422
1/0

Member Middle South Utilities System