

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	3	2	8	7	1	1	1	1	8	3	8	1	2	0	9	8	3	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DUCTET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

0 2 | With unit 2 in mode 1 (30% Rx power) at 2245 CST on 11/11/83, rod position indicator

0 3 | for rod M-2 on shutdown bank 'A' was declared inoperable due to reading erratic.

0 4 | The unit complied with action statement 'a' of LCO 3.1.3.2. There was no effect

0 5 | upon public health or safety. Previous occurrences - four (SQRO-50-327/80186,

0 6 | 80192, 82087, 82055).

07		08		09	
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE	
R	B	E	G	I N S T R U	
9	10	11	12	13	
COMP. SUBCODE		VALVE SUBCODE		SEQUENTIAL REPORT NO.	
X	Z	1		6 3	
19	20	21		22	
OCCURRENCE CODE		REPORT TYPE		REVISION NO.	
0	L	—		0	
28	29	30		31	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT	
X	Z	Z		Z	
33	34	35		36	
SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED	
Z	0 0 0 0	N		N	
37	40	41		42	
NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
N	L	X		9 9	
43	44	45		46	

1 0 Troub. shooting the rod position indicator revealed dirty contacts on the rod M-2

1 1 amplifier board. The contacts were cleaned and the indicator returned to service

1 2 at 0115 CST on 11/12/83. No further action is planned.

1	4													
1	5	E	28	0	3	0	29	NA	30	B	31	Operator observation	32	
1	6	Z	33	Z	34	NA			35	NA				36
1	7	0	0	0	37	Z	38	NA						39
1	8	0	0	0	40	NA								41
1	9	Z	42	NA										43
2	0	N	44	NA										45

8312200210 831209  
PDR ADOCK 05000328  
S PDR

NRC USE ONLY

NRC USE ONLY v

US  
ATTN  
83 DEC 14 All: 19  
TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

December 9, 1983

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta Street, NW.  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 2 - DOCKET  
NO. 50-328 - FACILITY OPERATING LICENSE DPR-79 - REPORTABLE OCCURRENCE  
REPORT SQRO-50-328/83163

The enclosed report provides details concerning the inoperability of one  
rod position indicator. This report is submitted in accordance with  
Sequoyah unit 2 Technical Specification 6.9.1.13.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*H. J. Green*  
H. J. Green  
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute of Nuclear Power Operations  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

NRC Inspector, Sequoyah

OFFICIAL COPY

1622  
1/1