



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

December 13, 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Special Report 83-11C/0 - Fire  
Door 1A320 Blocked Open to  
Support Planned Maintenance  
Activities  
AECM-83/0790

On November 10, 1983, fire door 1A320 to the Main Steam Tunnel Room was blocked open to support planned maintenance activities. Fire watches were established in accordance with Technical Specification 3.7.7 as part of the planned activities.

The door is expected to be restored by January 16, 1984. This is submitted as a Special Report pursuant to Technical Specification 6.9.2. This is a final report.

Yours truly,

L. F. Dale

Manager of Nuclear Services

EBS/SHH:sap

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

OFFICIAL COPY

IF22  
1/0