



Public Service of New Hampshire

SEABROOK STATION
Engineering Office:
1671 Worcester Road
Framingham, Massachusetts 01701
(617) - 872 - 8100

December 5, 1983

SBN- 591
T.F. Q2.2.2

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Attention: Mr. Richard W. Starostecki, Director
Division of Project and Resident Programs

References: (a) Construction Permits CPPR-135 and CPPR-136, Docket
Nos. 50-443 and 50-444
(b) Telecon of July 14, 1983, A. L. Legendre (YAEC) to
Eugene Kelley (NRC Region I)
(c) PSNH Letter, dated August 12, 1983, "Interim, 10CFR50.55(e)
Reports; Attachments to NNS-1 Pipe Supports and Service Air
System NNS Supports", J. DeVincentis to R. W. Starostecki
(d) PSNH Letter, dated September 28, 1983, "Interim
10CFR50.55(e) Report; Attachments to NNS-1 Pipe Supports
and Service Air System NNS Supports", J. DeVincentis to
R. W. Starostecki
(e) PSNH Letter, dated November 10, 1983, "Interim
10CFR50.55(e) Report; Attachments to NNS-1 Pipe Supports
and Service Air System NNS Supports", J. DeVincentis to
R. W. Starostecki

Subject: 10CFR50.55(e) Non-Reportability Determination: Attachments to
NNS-1 Pipe Supports

Dear Sir:

We have determined that the subject potentially reportable 10CFR50.55(e)
item is not reportable for the reasons delineated below. This is considered
to be the final report on this item.

The subject potentially reportable deficiency was based on the attachment
of cable tray supports to existing NNS-1 pipe supports. It was indicated that
the pipe support calculations did not account for the loads induced by the
cable tray support.

8312200380 831205
PDR ADOCK 05000443
S PDR

110

Generally, other disciplines do not attach to NNS-I pipe supports. Exceptions do exist in specific cases, these cases were identified through two methods.

1. Interference Elimination Team (IET)


The IET identified potential interferences prior to construction so that supports could be relocated or combined into multiple discipline supports in a controlled pre-engineered fashion.

2. Those supports specifically designed as multiple discipline supports.

A review of the IET work was undertaken, and it was concluded that for permanent multiple discipline supports, installed, existing analysis accounts for all loadings.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY


John DeVincentis
Project Manager

cc: Atomic Safety and Licensing Board Service List

Director, Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

William S. Jordan, III, Esquire
Harmon & Weiss
1725 I Street, N.W. Suite 506
Washington, DC 20006

Roy P. Lessy, Jr., Esquire
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Robert A. Backus, Esquire
116 Lowell Street
P.O. Box 516
Manchester, NH 03105

Philip Ahrens, Esquire
Assistant Attorney General
Department of the Attorney General
Augusta, ME 04333

Mr. John B. Tanzer
Designated Representative of
the Town of Hampton
5 Morningside Drive
Hampton, NH 03842

Roberta C. Pevear
Designated Representative of
the Town of Hampton Falls
Drinkwater Road
Hampton Falls, NH 03844

Mrs. Sandra Gavutis
Designated Representative of
the Town of Kensington
RFD 1
East Kingston, NH 03827

Jo Ann Shotwell, Esquire
Assistant Attorney General
Environmental Protection Bureau
Department of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108

Senator Gordon J. Humphrey
U.S. Senate
Washington, DC 20510
(Attn: Tom Burack)

Diana P. Randall
70 Collins Street
SEabrook, NH 03874

Donald E. Chick
Town Manager
Town of Exeter
10 Front Street
Exeter, NH 03833

Brentwood Board of Selectmen
RED Dalton Road
Brentwood, New Hampshire 03833

Edward F. Meany
Designated Representative of
the Town of Rye
155 Washington Road
Rye, NH 03870

Calvin A. Canney
City Manager
City Hall
126 Daniel Street
Portsmouth, NH 03801

Dana Bisbee, Esquire
Assistant Attorney General
Office of the Attorney General
208 State House Annex
Concord, NH 03842

Anne Verge, Chairperson
Board of Selectmen
Town Hall
South Hampton, NH 03842

Patrick J. McKeon
Selectmen's Office
10 Central Road
Rye, NH 03870

Carole F. Kagan, Esq.
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Angie Machiros
Chairman of the Board of Selectmen
Town of Newbury
Newbury, MA 01950

Town Manager's Office
Town Hall - Friend Street
Amesbury, Ma. 01913

Senator Gordon J. Humphrey
1 Pillsbury Street
Concord, NH 03301
(Attn: Herb Boynton)

Richard E. Sullivan, Mayor
City Hall
Newburyport, MA 01950