



Gilbert/Commonwealth engineers and consultants

GILBERT ASSOCIATES, INC., P. O. Box 1498, Reading, PA 19603/Tel. 215-775-2600/Cable Gilasoc/Telex 836-431

December 13, 1983

W.F. SAILER
General Manager
Quality Assurance Division.

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Washington, DC 20555

Attention: Mr. R. C. DeYoung

Re: Reportable Events
RCIC System Equipment Room Cooler
and Automatic Restart of Chillers

Dear Mr. DeYoung:

This is to provide an update on the referenced items which were reported in two letters dated April 29, 1983 and followed up on June 30, 1983.

A safe shutdown systems review has been completed on the Perry Nuclear Project. The purpose of the review was to assess system interaction to assure that automatic or manual start of support systems is provided. Results of the review are:

- o 18 systems required no design changes and no document changes.
- o 21 systems required only minor corrections to documentation. None of these will result in hardware changes.
- o 9 systems required design changes. These involved the addition of relays and other wiring changes. Two of the nine changes may have been considered as potentially reportable under 10CFR21, had they not been discovered during the investigation and corrective action process for events already reported.

If you require any further information on this matter, please call me at (215)775-2600, Extension 7543.

Very truly yours,

W. F. Sailer

WFS:kb

cc: H. Lorenz
T. M. Demers
R. C. DeYoung - 2
U. Potapovs - NRC Region IV

Document Management Branch
M. R. Edelman, VP Nuclear - CEI
C. M. Shuster, Nuclear QA Manager - CEI

8312200391 831213
PDR ADOCK 05000440
S PDR

Principal Offices

100 Lancaster Avenue, Reading, PA/Morgantown Road, Green Hills, Reading, PA 215 775-2600

209 East Washington Avenue, Jackson, MI 517 788-3000/One Exchange Place, Suite 1003, Jersey City, NJ 201 451-5220

IE19
1/0