



Carolina Power & Light Company

P. O. Box 163, New Hill, North Carolina 27562
December 9, 1983

FILE: SH N-2/18
Item 153

MQAH 83-390

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest
Atlanta, Georgia 30303

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400
ALUMINUM MYLAR SHIELDING TAPE

Dear Mr. O'Reilly:

This is to confirm the December 9, 1983 telephone conversation between Mr. K. V. Hate' (CP&L) and Mr. R. Carroll (NRC). Mr. Carroll was informed that the November 14, 1983 potentially reportable item, pertaining to cable manufactured by American Insulated Wire Company that was supplied with aluminum foil mylar shielding tape in lieu of copper tape, has been evaluated and considered not to be reportable per the provisions of 10CFR50.55(e) and 10CFR, Part 21.

Thank you for your consideration in this matter.

Yours very truly,

NJC/mt

cc: Mr. R. C. DeYoung
Mr. G. Maxwell
Mr. R. L. Prevatte

N. J. Chiangi - Manager
Quality Assurance/Quality Control
Harris Plant

8312200475 831209
PDR ADOCK 05000400
S PDR

OFFICIAL COPY

1627

1/0