

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

W. L. STEWART  
VICE PRESIDENT  
NUCLEAR OPERATIONS

December 14, 1983

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
Attn: Mr. James R. Miller, Chief  
Operating Reactors Branch No. 3  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No: 456D  
PSE&C/HSM/lmf/0014N  
Docket Nos. 50-388  
50-399  
License Nos. NPF-4  
NPF-7

Gentlemen:


ADDITIONAL INFORMATION  
PROPOSED OPERATING LICENSE AMENDMENT NPF-4 AND NPF-7  
NORTH ANNA POWER STATION UNIT NOS. 1 AND 2

In a recent telephone conversation between Vepco and members of your staff, clarification was requested as to the materials of construction of the neutron absorber spent fuel rack leveling pads and leveling screws.

The leveling pads are constructed of 304 stainless steel (ASTM A240). The leveling screws are constructed of 17-4 PH Stainless Steel (ASTM A564 Gr630) with a chrome plating to prevent galling.

If you require further information on this matter, we would be pleased to meet with your staff at their convenience.

Very truly yours,

  
W. L. Stewart

cc: Mr. James P. O'Reilly  
Regional Administrator  
Region II  
U. S. Nuclear Regulatory Commission  
Atlanta, Georgia 30303

Mr. M. W. Branch  
NRC Resident Inspector  
North Anna Power Station

8312200488 831214  
PDR AD0CK 05000388  
P PDR

A001  
1/0