

Attachment to AECM-83/0785

CONTROL BLOCK:

PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION

CON'T

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)080910

1000

PHONE _____

NRC USE ONLY

6
7
8
9
10



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

December 12, 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
RPS Electrical Protection
Assembly Channel "C" Under-
Voltage Trip Setpoints Out
of Tolerance
LER 83-181/03 L-0
AECM-83/0785

On November 11, 1983, while performing calibration of RPS electrical protection assembly channel "C", the "as found" setpoints for under-voltage trip were 116.2VAC. This is contrary to Technical Specification 4.8.4.3 which requires the under-voltage trip setpoints to be 117VAC. This is reported pursuant to Technical Specification 6.9.1.13.a. Attached is interim LER 83-181/03 L-0.

Yours truly,

L. F. Dale

L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap
Attachment

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

JEZ
||

Member Middle South Utilities System