

GEORGIA POWER COMPANY BOARD OF DIRECTORS BRIEFING
NUCLEAR PLANTS STATUS
JUNE 20, 1990

HATCH

UNIT 1

- Off-Line due to reactor scram on low water level.
- On June 20, 1990, while in the process of reducing load due to unexplained high condensor level, the feed pump failed to keep adequate flow to the vessel and the unit scrambled on low water level.
- On June 6, 1990, Unit 1 tied to the grid completing a scheduled one-hundred ten (110) day refueling and condenser retube outage, twenty six (26) hours ahead of schedule.
- Unit 1 was shutdown on June 10, 1990, due to a problem in the turbine off-gas filtering system. Plant management subsequently declared a Notification of Unusual Event after receiving further information about the problem. The NUE was terminated on June 16. The unit returned to service on June 17. No significant damage was sustained by the off-gas system.
- Next Refueling Date for Unit 1 is September 18, 1991 *Suzder*

UNIT 2

- 100% Power
- 82 Days On-Line
- No Major Problems
- Next Refueling Date for Unit 2 is September 20, 1991.

- On April 30, 1990, an INPO Evaluation Team began its periodic on-site evaluation of Plant Hatch. The evaluation team continued its work at the site through May 11, 1990. The plant debriefing by INPO did not appear to have any major problems identified. The corporate exit was held June 13, 1990.

*INPO
last 2 days**Rated 1*

(Continued)

NUCLEAR REGULATORY COMMISSION

Docket No. 50-424-OLA-3 Official Exh. No. Int. 104
In the matter of Vogtle Units 1 & 2
Staff IDENTIFIED ✓
Applicant RECEIVED
Intervenor ✓ REJECTED
Cont'g Off'r
Contractor DATE 04-20-95
Other Witness Houston
Reporter S. Zilinski

GPC BOD Briefing
Nuclear Plants Status
June 20, 1990
Page 2

VOGTLE

UNIT 1

- 100% Power
- 43 Days On-Line
- No Major Problems
- Next Refueling Date for Unit 1 is September 13, 1991.
- The NRC IIT Report on the March 30, 1990 Vogtle Loss of Power Event was issued on June 8, 1990. — *Some news 2-4 weeks*
Present to Commission

UNIT 2

- 94.9% Power
- 45 Days On-Line
- No Major Problems
- Unit 2 commenced coastdown on June 18, 1990.
- Next Refueling Date for Unit 2 is September 14, 1990.