

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

7

PHONE _____



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

December 25, 1983
02 DEC 25 11:08

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - LPCS Injection
Valve Leakage Pressure
Monitor Alarm Setpoint
Found Greater Than
Technical Specification
Setpoint Value
LER 83-157/03 X-1
AECM-83/0795

This letter submits an update to a previous report submitted on November 3, 1983. The event for which the report was submitted occurred on October 4, 1983, during performance of the monthly functional test, when the LPCS injection valve leakage pressure monitor alarm setpoint was found at 52 psig. Technical Specification Table 3.4.3.2-2 requires the alarm setpoint to be less than or equal to 50 psig. A Limiting Condition for Operation was entered pursuant to Action (d) of Technical Specification 3.4.3.2. This was reported pursuant to Technical Specification 6.9.1.13.b.

Our investigation into the cause of the event and corrective actions for the event are complete. Attached is LER 83-157/03 X-1 which is a final report.

Yours truly,

L. F. Dale

for L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap
Attachment

cc: (See Next Page)

OFFICIAL COPY

1122

1/1

MISSISSIPPI POWER & LIGHT COMPANY

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555