



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

December 28, 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D. C. 20555

Attention: Mr. Harold R. Denton, Director

Dear Mr. Denton:

SUBJECT: Grand Gulf Nuclear Station
Units 1 and 2
Docket Nos. 50-416 and 50-417
License No. NPF-13
File 0260/L-860.0
Confirmation of BOP/PGCC
Panel Qualification
AECM-83/0815

In letter AECM-83/0667, dated October 14, 1983, Mississippi Power & Light committed to complete a retest of a Bourns Potentiometer by December 15, 1983, and to provide the results of that retest by December 31, 1983. This submittal documents successful completion of the retest and qualification of the potentiometer to IEEE-323, 1974 and to IEEE-344, 1975. This constitutes the last of the devices involved in the BOP/PGCC qualification test program.

Please contact this office if additional information is required.

Yours truly,

L. F. Dale
Manager of Nuclear Services

JHS/JGC:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee

Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. J. P. O'Reilly, Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

8312300090 831228
PDR ADOCK 05000416
P PDR

Boo
1/0

Member Middle South Utilities System