

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE									
7	8	L	6	0	5	0	-	0	3	2	5	7	1	1	1	9	8	3	8	1	2	1	9	8	3	9															
		60	61	DOCKET NUMBER										69	EVENT DATE										74	75	REPORT DATE										80				

0 2 | During unit power operation performance of the primary containment volumetric average
0 3 | air temperature derivation, PT-16.2, revealed that primary containment multipoint
0 4 | temperature recorder, 1-CAC-TR-1258, was showing temperature indications, but was
0 5 | printing erratically. This event did not affect the health and safety of the public.
0 6 |
0 7 |
0 8 | Technical Specifications 3.3.5.3, 6.9.1.9b

SYSTEM CODE I D		CAUSE CODE E		CAUSE SUBCODE E		COMPONENT CODE I N S T R U				COMP SUBCODE R		VALVE SUBCODE Z	
EVENT YEAR 8 3		SEQUENTIAL REPORT NO. 0 5 7		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0					
ACTION TAKEN X	FUTURE ACTION F	EFFECT ON PLANT Z	SHUTDOWN METHOD Z	HOURS 0 0 0 0	ATTACHMENT SUBMITTED N	NPRD-4 FORM SUB. Y	PRIME COMP. SUPPLIER N	COMPONENT MANUFACTURER B 4 5					

1 0 TR-1258 printed erratically due to dirty electrical contacts in the recorder control
1 1 board timing relay. The contacts were cleaned and TR-1258, Model No. 550, was re-
1 2 turned to service. Due to a history of similar events involving the TR-1258 recorders
1 3 of both units, they will be replaced in 1984 in accordance with appropriate plant modi-
1 4 fications.

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521



Carolina Power & Light Company

Brunswick Steam Electric Plant

P. O. Box 10429

Southport, NC 28461-0429

December 19, 1983

FILE: B09-13510C

SERIAL: BSEP/83-3982

Mr. James P. O'Reilly, Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1

DOCKET NO. 50-325

LICENSE NO. DPR-71

LICENSEE EVENT REPORT 1-83-57

Dear Mr. O'Reilly:

In accordance with Section 6.9.1.9b of the Technical Specifications for Brunswick Steam Electric Plant, Unit No. 1, the enclosed Licensee Event Report is submitted. This report fulfills the requirement for a written report within thirty (30) days of a reportable occurrence and is in accordance with the format set forth in NUREG-0161, July 1977.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/ag/LETJ03

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

OFFICIAL COPY

1622

11