



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

December 12, 1983

Dr. Thomas E. Murley
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-161/01P-0
ER 100450 FILE 841-23
PLA- 1999

Docket No. 50-387
License No. NPF-14

Dear Dr. Murley:

This transmission confirms the telephone report of December 10, 1983, by M.W. Gmyrek to G.G. Rhoads of your staff, concerning the Reactor Coolant system temperature being allowed to increase to approximately 150°F while in Operational Condition 5 (Refueling). This condition was corrected and the temperature is being maintained $\leq 140^\circ\text{F}$.

This condition is considered reportable in accordance with Technical Specification 6.9.1.8(b), and additional information regarding circumstances of the incident and corrective actions to be taken will be provided in the fourteen day follow-up report.

H.W. Keiser
Superintendent of Plant-Susquehanna

JTT/pjg

cc: G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8401030184 831212
PDR ADDCK 05000387
S PDR

11
IEU