

CONTROL BLOCK:

--	--	--	--	--	--	--

 (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1
7	3

REPORT SOURCE

L	5	0	5	0	0	0	2	5	1	7	1	1	2	3	8	3	3	1	2	2	2	8	3	9				
50	81	SOCKET NUMBER										58	59	EVENT DATE						74	75	REPORT DATE						30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

03 During an outage of Unit 4, full-flow recirc piping was added to the 4A and 4B high
03 head safety injection pump discharge piping. When returning the unit to operation, the
04 reactor was taken critical before the newly modified discharge piping was hydrotested
05 at pump discharge pressure with a qualified inspector present. This is reportable under
06 T.S.6.9.2.b.3. The new welds had been liquid-penetrant tested. A system operability
07 test at the pump discharge pressure was successfully completed several days earlier.
03 The public's health and safety were not affected. A similar LER was 250-82-015.

SYSTEM CODE 0 9		CAUSE CODE S F		CAUSE SUBCODE A		COMPONENT CODE Z Z Z Z Z Z						COMP SUBCODE Z		VALVE SUBCODE Z	
7 8		9 10		11 12		13 14		15 16		17 18		19 20			
(17) LER/RO REPORT NUMBER		EVENT YEAR 8 3		SEQUENTIAL REPORT NO. 0 2 0		OCCURRENCE CODE /		REPORT TYPE L		REVISION NO. 0					
21 22		23 24		25 26		27 28		29 30		31 32					
ACTION TAKEN X		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED N		NPRO-4 FORM 308 PRIME COMP SUPPLIER N Z			
33 34		35 36		37 38		39 40		41 42		43 44		45 46			
(18) (19)		(20)		(21)		(22)		(23)		(24)		(25)			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A lower pressure, 10-year hydrotest performed a week earlier was mistakenly consid-
1 1 ered to have satisfied the design package's hydrotest requirement. The misunderstand-
1 2 ing between between the concerned departments was resolved, the required hydrostatic
1 2 test was completed within approx. 5 hours after criticality, and corrective actions have
1 4 been taken in the form of increased management attention to this area.

FACILITY STATUS (13) 0 POWER (29) N/A OTHER STATUS (30)
 METHOD OF DISCOVERY (31) Operator observation DISCOVERY DESCRIPTION (32)
 ACTIVITY CONTENT (33) Z RELEASED OF RELEASE (34) Z/N/A AMOUNT OF ACTIVITY (35)
 LOCATION OF RELEASE (36) N/A

PERSONNEL EXPOSURES										
NUMBER			TYPE	DESCRIPTION						
1	7	0	0	0	17	Z	38	N/A		

PERSONNEL INJURIES		30
NUMBER	DESCRIPTION	
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40	N/A	

		7						8						9						10						11						12						13						14						15						16						17						18						19						20						21						22						23						24						25						26						27						28						29						30					
		LOSS OF OR DAMAGE TO FACILITY																								(4)																																																																																																																							
		TYPE DESCRIPTION																																																																																																																																															
		Z(4) N/A																																																																																																																																															

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

PUBLICITY

ISSUED DESCRIPTION (45)

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

IE22 NRC USE ONLY

NAME OF PREPARER Z. E. Berry

PHONE 305/245-2910 ext. 353

8401030210 831222
PDR ADCK 05000251
S PDR



December 22, 1983
PNS-LI-83-749

Mr. James P. O'Reilly
Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

REPORTABLE OCCURRENCE 251-83-020

TURKEY POINT UNIT 4

DATE OF OCCURRENCE: NOVEMBER 23, 1983

TECHNICAL SPECIFICATION 6.9.2

HIGH HEAD SAFETY INJECTION PUMPS

The attached Licensee Event Report is being submitted in accordance with Technical Specification 6.9 to provide 30-day notification of the subject occurrence.

Very truly yours,

H. W. Williams, Jr.

J. W. Williams, Jr.
Vice President
Nuclear Energy Department

JWW/PKG/js

Attachment

cc: Director, Office of Inspection and Enforcement (30)
Harold F. Reis, Esquire
File 933.1 TP

OFFICIAL COPY

IE 22
11