

3150-0011

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	C	A	D	C	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	9					14	15												25	26					30			57	CAT	58
LICENSEE CODE		LICENSE NUMBER																LICENSE TYPE													

CON'T

01 REPORT SOURCE L 6 0 5 0 0 0 2 7 5 7 1 1 1 6 8 3 8 1 2 1 6 8 3 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 In Mode 5, it was discovered that Technical Specification Surveillance Require-  
03 ment 4.3.3.3.1, Channel Functional Test of the Triaxial Time-History Accelerographs,  
04 which was due on November 16, 1983, had not been performed. The accelerographs are  
05 for recording purposes only. This event has in no way affected the public's health  
06 and safety. Reportable per Technical Specification Section 6.9.1.13b.  
07  
08

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMP. SUBCODE		VALVE SUBCODE	
0	9	I	F	A	C	I	N	R	Z
7	8	9	10	11	12	13	14	15	16
EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.	
8	3	0	3	0	/	0	3	L	0
21	22	23	24	25	27	28	29	30	31
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS	
E	H	Z	Z	0	0	0	0	Y	N
18	19	20	21	22	23	24	25	26	27
PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER		ATTACHMENT SUBMITTED		NFRD-4 FORM SUB.		REVISION NO.	
L	K	0	6	7	Y	N	L	0	0
28	29	30	31	32	33	34	35	36	37

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

Personnel responsible for scheduling the surveillance test overlooked this particular test. Immediately upon its discovery, the preliminary surveillance test requirements were undertaken. On December 3, 1983, the system was returned to operable status. The responsible personnel have been counseled on the importance of maintaining compliance with the Technical Specifications.

FACILITY STATUS      % POWER      OTHER STATUS (30)      METHOD OF DISCOVERY      DISCOVERY DESCRIPTION (32)

1 5 H (28) 0 0 0 (29) NA A (31) During programmatic review

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 7 8 9 10 11 NA NA

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION	
1	7	0	0	37	38
				NA	

PERSONNEL INJURIES										
NUMBER				DESCRIPTION						
1	8	0	0	0	0	40	NA			

LOSS OF OR DAMAGE TO FACILITY  
TYPE DESCRIPTION (43)  
1 9 Z (42) NA 8401030250 831216  
7 8 9 10 PDR ADOCK 05000275  
S PDR

PUBLICATION  
ISSUED DESCRIPTION (45) NA

7 8 9 10

NRC USE ONLY

42 43 44 45 46 47 48 49 50

NAME OF PREPARER William W. Kessinger

PHONE 805/541-7484

ATTACHMENT TO  
LER 83-030/03L-0  
DIABLO CANYON NUCLEAR POWER PLANT  
DOCKET NO. 50-275  
LICENSE NO. DPR-76

SUPPLEMENTAL INFORMATION ON CORRECTIVE ACTION

The Channel Functional Test of the Triaxial Time-History Accelographs which was accomplished on December 1, 1983, required vendor participation. On December 3, 1983, the plant personnel who participated in the Channel Functional Test verified that the system performed satisfactorily and the system was then returned to operable status.

RECEIVED  
NRC

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

1983 DEC 19 PM 12:17  
77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER  
MANAGER

REGION VISE

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
NUCLEAR POWER GENERATION

December 16, 1983

Mr. John B. Martin, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, CA 94596-5368


Re: Docket No. 50-275, OL-DPR-76  
Diablo Canyon Unit 1  
License Event Report 83-030/03L-0  
Missed Surveillance Requirement

Dear Mr. Martin:

Pursuant to Section 6.9.1.13b of the Technical Specifications, Appendix A to the Diablo Canyon Unit 1 Operating License, the enclosed Licensee Event Report is submitted concerning a missed Technical Specification Surveillance Requirement within the specified time interval.

This event has in no way affected the public's health and safety.

Sincerely,



cc: G. W. Knighton

Director, Office of Management Information  
and Program Control

Service List

Per Rgn V  
LF-34  
1/1