NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NYNMP1 (2) | 00-00000-00 (3) | 4111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — SU CAT

CON'T
01 | REPORT SOURCE L (6) | 0500022 0 (7) | 112283 (8) | 120983 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operations the Fuel Zone Water Level Measuring System
03 (Accurex) was taken out of service, one channel at a time, to modify it's
04 program to improve its accuracy. Consequences were minimal, as the
05 devices were each returned to service within one hour, well within the
06 seven days permitted by Tech. Specs. There were no negative effects on
07 public health or safety resulting from this occurrence.
08

09 SYSTEM CODE ZZ (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Y (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 83 — SEQUENTIAL REPORT NO. 042 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN F (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The Accurex was modified as per General Electric Recommendations and was
11 returned to service within one hour. Inspection NI-ISP-36-ICC was
12 performed by I&C following the completion of the modification, after
13 which the Accurex was then declared operable.
14

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) REVIEW

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION NA

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

IE22

NAME OF PREPARER A.R. SCHWEDT PHONE (315) 349-2616

8401030263 831209
PDR ADOCK 05000220
S PDR