



INDIANA & MICHIGAN ELECTRIC COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

December 13, 1983


Mr. J.G. Keppler, Regional Administrator
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-58/74
Docket No. 50-315/50-316

Dear Mr. Keppler:

Pursuant to the requirements of Appendix B, Part II, Nonradiological Environmental Protection Plan, Section 3.2, a copy of the report to the Michigan Water Resources Commission notifying them of the failure to take the Steam Generator blowdown suspended solids sample on November 2, 1983, is attached. This report is required by Amendment No. 54 to Facility Operating License No. DPR-58 and Amendment No. 40 to Facility Operating License No. DPR-74 dated May 6, 1982.

Sincerely,


W.G. Smith, Jr.
Plant Manager

/bab

Attachment

cc: John E. Dolan
M.P. Alexich
R.F. Kroeger
H. Brugger
E.R. Swanson, RO:III
R.C. Callen, MPSC
G. Charnoff, Esq.
J.M. Hennigan
PNSRC
J.F. Stietzel
E.L. Townley
K.R. Baker
R.O. Bruggee, EPRI

INFO
Dir., IE (20 copies)
Dir., MIPC (2 copies)
H.R. Denton

8401050678 831213
PDR ADOCK 05000315
S PDR

DEC 22 1983

IE2211



INDIANA & MICHIGAN ELECTRIC COMPANY

ONE SUMMIT SQUARE, P.O. BOX 60, FORT WAYNE, IN. 46801
Telephone (219) 425-2111

November 23, 1983

WILLIAM A. BLACK

President

Mr. Paul D. Zuger
Executive Secretary
Michigan Water Resources Commission
Stevens T. Mason Building
Box 30026
Lansing, MI. 48909

Re: D. C. Cook Nuclear Plant
NPDES Permit No. MI0005827
Steam Generator Blowdown

Dear Mr. Zuger:

A review of monitoring records indicate the steam generator blowdown suspended solids sample was not taken on November 2, 1983. The #1 Nuclear Steam Supply System which had been at 48 percent power level for several days commenced power ascension at 0510 hours on October 31. The unit reached 95 percent reactor power at 1530 hours on November 1. During the next day, November 2, the blowdown system was on the startup blowdown flash tank or out-of-service where no sample was available for the majority of the day. During the brief use of the normal flash tank, sampling did not occur.

The system operated on the normal running flash tank November 3 when daily sampling was resumed.

Very truly yours,

W. A. Black

W. A. Black
President

WAB/be

cc: W. G. Smith

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

W. A. Black

W. A. Black