

50-329  
50-330

PRINCIPAL STAFF	
RA	DRP
D/RA	DE
A/RA	DRMSF
RC	DRMA
PAO	SCS
SGA	ML
INF	File

*orig 3*

ST. STONE AND WEBSTER MICHIGAN, INC.  
P.O. BOX 1963, MIDLAND, MICHIGAN 48640

DATE	1/3/83
J. O. NO.	14509
P. O. NO.	N/A
LTR. NO.	83-0003
REF.	N/A

VIA

TO

D. L. QUAMME, CPCo Midland (site)

DEAR SIRs:

THE FOLLOWING ARE ☐ ATTACHED: ☐ SENT SEPARATELY:

COPIES	PRINTS	REPRODUCIBLES	MICROFILM APERTURE CARDS
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

STATUS		PLEASE NOTE	SENT FOR YOUR	
<input type="checkbox"/> FINAL	<input checked="" type="checkbox"/> APPROVED	<input type="checkbox"/> REVISIONS	<input type="checkbox"/> OMISSIONS	<input type="checkbox"/> APPROVAL <input type="checkbox"/> COMMENT
<input type="checkbox"/> PRELIMINARY	<input type="checkbox"/> APPROVED AS REVISED AS DEFINED IN SPECIFICATION	<input type="checkbox"/> ADDITIONS	<input type="checkbox"/> CORRECTIONS	<input type="checkbox"/> USE <input type="checkbox"/> INFORMATION
<input type="checkbox"/> NO COMMENT	<input type="checkbox"/> UNACCEPTABLE	<input type="checkbox"/> COMMENTS	<input type="checkbox"/>	<input type="checkbox"/> FILES <input type="checkbox"/> CONCURRENCE
<input type="checkbox"/> SUGGESTIONS AS NOTED	<input type="checkbox"/>			

YOUR ATTENTION IS DIRECTED TO THE FOLLOWING:

RELEASED FOR: <input type="checkbox"/> FABRICATION <input type="checkbox"/> PURCHASE OF NECESSARY MATERIALS	
<input type="checkbox"/> PLEASE REVISE AND SUBMIT	<input type="checkbox"/> PRINTS <input type="checkbox"/> REPRODUCIBLES <input type="checkbox"/> MICROFILM APERTURE CARDS
<input type="checkbox"/> PLEASE SUBMIT	<input type="checkbox"/> PRINTS <input type="checkbox"/> REPRODUCIBLES <input type="checkbox"/> MICROFILM APERTURE CARDS OF <input type="checkbox"/> DOCUMENTS <input type="checkbox"/> DRAWINGS <input type="checkbox"/> SHOP DETAIL
<input type="checkbox"/> PLEASE RETURN ONE COPY EACH OF THIS MATERIAL BEARING YOUR APPROVAL OR COMMENTS.	
<input type="checkbox"/> PLEASE ACKNOWLEDGE RECEIPT OF THIS MATERIAL BY SIGNING AND RETURNING THE ENCLOSED COPY OF THIS FORM.	
<input type="checkbox"/> WE TRUST THAT THESE NOTES ARE IN ACCORDANCE WITH YOUR UNDERSTANDING. IF NOT, PLEASE ADVISE US.	

IMPORTANT SHOULD ANY REVISION TO DOCUMENTS OR DRAWINGS RETURNED HERewith INVOLVE A PRICE INCREASE THE SUPPLIER MUST NOTIFY STONE & WEBSTER PURCHASING DEPARTMENT WITHIN TEN (10) DAYS EVEN THOUGH A DEFINITE ESTIMATE CANNOT BE GIVEN AT THE TIME. OTHERWISE, THE PURCHASER WILL CONSIDER THE REVISIONS MADE WITHOUT COST.

CIO NIR 012 is forwarded for appropriate action

cc: JGKeppler, NRC  
JJHarrison, NRC  
RJCook, NRC  
RAWells, CPCo

*S. W. Baranow*  
S. W. Baranow  
Program Manager

ATTACHMENTS

8401100465 840103  
PDR ADOCK 05000329  
S PDR

JAN 6 1984

*IEO*

STONE AND WEBSTER ENGINEERING CORPORATION  
NONCONFORMANCE IDENTIFICATION REPORT

Page 1 of 2  
QCI 15.01  
Attachment 4.1  
Revision 2

DATE OF NONCONFORMANCE: January 2, 1984		NIR NUMBER 012
<u>IDENTIFICATION/LOCATION OF ITEMS:</u> Civil Review Phase III FCR/FCN Midland CIO Office Drawings Stations 8-10-13		
<u>DESCRIPTION OF NONCONFORMANCE:</u> Station 8: FSK Drawings in station 8 do not agree with Bechtels Master Composite Register, the revision column and the sheet column appears to be a problem. This is a generic problem with the CIO's sampled FSK's. Station 10: 1) The following Design Drawings and Specifications have inconsistent quantity distribution. The Bechtel FDDL quantity does not agree with the actual count in the field station. Specification # C-195, C-197, C-198, C-200. Design Drawings # C-1492, C-1493-1, C-97, C-8 and C-2031. 2) All vendor controlled drawings have one copy in their station that is voided. This practice can not be verified per procedure. 3) Spencer-White and Prentice had the following Design Drawings missing from station 10, one copy (sepia) of C-8 and one copy (sepia) of C-97. Two sepia were issued for each drawing per Bechtels FDDL. 4) Design Drawing C-2031-19 revision 1 did not have FCR 6974 attached to the drawing. (continued on Page 2)		
R. Scallan INITIATOR		PROGRAM MGR <i>JS for SW Baranow</i>
DATE January 3, 1984		DATE <i>1/3/84</i>
CORRECTIVE ACTION BY: MPQAD		
IDENTIFY ORGANIZATION TAKING CORRECTIVE ACTION		
VERIFICATION	SAT	UNSAT
INITIATOR	NEW NIR#	
DATE	DATE	CONCURRENCE
PROGRAM MGR		DATE
REMARKS		

(5) -- pulled-back, the Composite Register did not. 6) Mergentime FSK CA 1062 Revision 6 - FCR C-6053 was on the blue-line (attached) but was not on the Sepia. 7) FSK 1060 shows in the Register as "FSK 1060 sheet 7", however it should indicate "FSK 1060 Revision 7 with only one sheet." 8) FSK 1062 shows in the Register as "FSK 1062 sheet 6 revision 4," however it should indicate "FSK 1062 revision 6 with only one sheet." 9) Specification C-305 located in station 10 Mergentime was missing the symbol ® to indicate that there is a retired document against this specification.

Station 13: Specification C-306 had referenced FCR C-4854 but it was not attached to the Specification. 2) Control Drawing C0482 sheet 1 outstanding attachment stamp could not be read. Also a ® symbol was located on the drawing while the Composite Register had it voided.