

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)0 1 | A | L | J | M | F | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CA 38

CONT

0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 4 | 8 | 7 | 1 | 2 | 0 | 1 | 8 | 3 | 8 | 1 | 2 | 2 | 2 | 8 | 3 | 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 0445 on 12/1/83, the #4 river water pump was declared inoperable due to a  
0 3 | broken lower pump bearing lube water supply line. Tech. Spec. 3.7.5, in part,  
0 4 | requires this pump to be operable. Tech. Spec. 3.7.5 action statement require-  
0 5 | ments were met. Health/safety of the public was not affected.

0 6 |

0 7 |

0 8 |

0 9 | SYSTEM CODE | W | G | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | D | 13 | COMPONENT CODE | P | U | M | P | X | X | 14 | COMP. SUBCODE | B | 15 | VALVE SUBCODE | Z | 16 |  
7 8 9 10 11 12 13 14 15 16

17 | LER/RO REPORT NUMBER | 8 | 3 | 21 | 22 | SEQUENTIAL REPORT NO. | 0 | 8 | 1 | 24 | 25 | OCCURRENCE CODE | 0 | 3 | 27 | 28 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32 |

ACTION TAKEN | A | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 37 | 38 | ATTACHMENT SUBMITTED | N | 23 | NPSD-4 FORM SUB. | Y | 24 | PRIME COMP. SUPPLIER | A | 25 | COMPONENT MANUFACTURER | B | 5 | 8 | 0 | 26 |  
33 34 35 36 37 38 39 40 41 42 43 44 45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event was caused by failure of the fitting between the supply line and the  
1 1 | lower pump bearing. The affected fitting was replaced, lube water restored, and  
1 2 | the #4 river water pump was declared operable at 0800 on 12/2/83.

1 3 |

1 4 |

1 5 | FACILITY STATUS | E | 28 | % POWER | 1 | 0 | 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Operational Event | 32 |  
7 8 9 10 11 12 13 14 15 16 17 18 19 201 6 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36 |  
7 8 9 10 11 12 13 14 15 16 17 18 19 201 7 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39 |  
7 8 9 10 11 12 13 14 15 16 17 18 19 201 8 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41 |  
7 8 9 10 11 12 13 14 15 16 17 18 19 201 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43 |  
7 8 9 10 11 12 13 14 15 16 17 18 19 202 0 | PUBLICITY ISSUED DESCRIPTION | N | 44 | DESCRIPTION | NA | 45 |  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

NAME OF PREPARER W. G. Hairston, III

PHONE (205) 899-5156

3401040136 831222  
PDR ADOCK 05000348  
S PDR