

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 ALJMF1200-000000-00034111145
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

CONT

01 REPORT SOURCE L605000348712028381222839
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 0410 on 12/2/83, during performance of FNP-1-STP-605.4 (Auxiliary Building
03 Battery Quarterly Verification), the A train auxiliary building battery was
04 declared inoperable due to low specific gravity on cell #40 (1.185 corrected to
05 77 degrees Fahrenheit actual versus ≥ 1.190 corrected to 77 degrees Fahrenheit
06 required). Tech. Spec. 3.8.2.3, in part, requires this battery to be operable.
07 Tech. Spec. 3.8.2.3 action statement requirements were met. Health/safety of the
08 public was not affected.

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
E C 11 X 12 Z 13 B A T T E R Y 14 Z 15 Z 16
17 LER/NO REGRT NUMBER 18 8 3 19 0 8 2 20 0 3 21 1 22 0 32 0
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 Z 19 Z 20 Z 21 0 0 0 0 22 N 23 Y 24 A 25 G 1 8 5 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 No cause for this event could be determined. The affected cell was placed on a
11 single cell charger and following satisfactory completion of FNP-1-STP-605.4, the
12 A train auxiliary building battery was declared operable at 0530 on 12/2/83.
13
14

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
E 28 1 0 0 29 NA B 31 Surveillance Test
16 ACTIVITY CONTENT LOCATION OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
Z 33 Z 34 NA
17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
0 0 0 37 Z 38 NA
18 PERSONNEL INJURIES NUMBER DESCRIPTION 41
0 0 0 40 NA
19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
Z 42 NA
20 PUBLICITY ISSUED DESCRIPTION 45
N 44 NA

8401040140 831222
PDR ADOCK 05000348
S PDR

NAME OF PREPARER W. G. Hairston, III

PHONE (205) 899-5156