



GPU Nuclear Corporation

Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

December 21, 1983

Director, Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Technical Specification Change Request No. 119

In response to conversations with your Staff concerning our original request of July 13, 1983 and the requirements of 10CFR50.91, GPU Nuclear is again requesting a change to Appendix A of the license. Our response relative to the 10CFR50.91 requirements has been modified to accommodate your needs.

In accordance with 10CFR50.59, 10CFR50.90 and 10CFR50.91, GPU Nuclear Corporation, operator of the Oyster Creek Nuclear Generating Station, Provisional Operating License No. DPR-16, requests changes to Appendix A of that license.

Pursuant to your correspondence of October 1, 1980 concerning long-term scram system reliability, section 3.1 and 4.2 of the Oyster Creek Technical Specifications shall be revised. The subject change request should become effective upon the completion of the modification, currently scheduled to be completed during the cycle 10 refueling outage. With respect to the scram discharge volume, water level trip settings of Table 3.1.1, the final trip settings will be determined and submitted upon completion of system testing.

The Technical Specification Change Request has been reviewed and approved by the Plant Operations Review Committee and the Independent Safety Review Group in accordance with Section 6.5 of the Oyster Creek Technical Specifications.

8401060148 831221
PDR ADOCK 05000219
P PDR

*Approval check
forward w/ original
submitted of 7/13/83*

Pursuant to 10CFR50.91(b)(1), a copy of this Technical Specification Change Request has been sent to the State of New Jersey Department of Environmental Protection. In addition, we have determined that this submittal is Class III per 10CFR170.22 and have forwarded a check for \$4,000, pursuant to that section, with our original submittal of July 13, 1983.

Very truly yours,



P. B. Friedler
Vice President and Director
Oyster Creek

lr

cc: Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406

NRC Resident Inspector
Oyster Creek Nuclear Generating Station
Forked River, N.J. 08731