


OYSTER CREEK NUCLEAR GENERATING STATION

Provisional Operating
License No. DPR-16

Technical Specification
Change Request No. 119
Docket No. 50-219


Applicant submits by this Technical Specification Change Request No. 119 to the Oyster Creek Nuclear Generating Station Technical Specifications, changes to Specification 3.1 and 4.2

By



P. B. Fiedler
Vice President and Director
Oyster Creek

Sworn and subscribed to before me this 21 day of December, 1983.


Notary Public

MICHAEL LAGGART
NOTARY PUBLIC OF NEW JERSEY
My Commission Expires December 31, 1985

8401060155 831221
PDR ADQCK 05000219
P PDR

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF
GPU NUCLEAR CORPORATION


)
) DOCKET NO. 50-219
)

CERTIFICATE OF SERVICE

This is to certify that a copy of Technical Specification Change Request No. 119 filed with the United States Nuclear Regulatory Commission on December 21, 1983, has this 21st day of December 1983 been served on the Mayor of Lacey Township, Ocean County, New Jersey by deposit in the United States mail, addressed as follows:

Mayor of Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

By



P. B. Fiedler
Vice President and Director
Oyster Creek



GPU Nuclear Corporation
100 Interpace Parkway
Parsippany, New Jersey 07054
201 263-6500
TELEX 136-482
Writer's Direct Dial Number:

December 21, 1983

Mayor of Lacey Township
818 West Lacey Road
Forked River, N.J. 08731

Dear Mayor:

Enclosed herewith is one copy of Technical Specification Change Request No. 119 for the Oyster Creek Nuclear Generating Station Operating License.

This document was filed with the United States Nuclear Regulatory Commission on December 21, 1983.

Very truly yours,

A handwritten signature in black ink, appearing to read "P. B. Fiedler", written over a horizontal line.

P. B. Fiedler
Vice President and Director
Oyster Creek

1r

Enclosure

OYSTER CREEK NUCLEAR GENERATING STATION
(DOCKET NO. 50-219)
PROVISIONAL OPERATING LICENSE NO. DPR-16

Applicant hereby requests the Commission to change Appendix A to the above captioned license as follows:

1. Section to be changed:

3.1 and 4.2

2. Extent of change:

Scram Dump Volume (SDV) modifications were performed at the Oyster Creek Nuclear Generating Station in accordance with the BWR Owners Group recommendations in response to IE Bulletin 80-17 and its supplements.

As a result of providing two SDV instrument volumes to monitor water accumulation, the high water level scram and rod block set points have been changed. Section 3.1 has been modified to reflect these changes. In addition, the scram discharge volume drain and vent valves closure times in Section 4.2 has been changed to be in agreement with the BWR Owners Group recommendations.

3. Changes requested:

Per the attached Technical Specification pages 3.1-4, 3.1-7, 3.1-7a, 3.1-11, 3.1-11a and 4.2-2.

4. Discussion:

The NRC presented their criteria for the modification of the scram discharge system in their letter of December 1, 1980. Our letters to the NRC dated December 17, 1980, March 4, 1981 and April 30, 1981 confirm that the SDV modification at the Oyster Creek Nuclear Generating Station will be in compliance with the NRC criteria.

The modification will ensure that there is sufficient volume available in the SDV to allow all 137 control rods to scram in the event that plant conditions warrant this action. The subject modification will enhance the safety of the plant, thereby providing a greater degree of protection for the health and safety of the public.