

RECEIVED
NRC
Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

1983 DEC -9 AM 10:56
November 30, 1983
ANPP-28324-BSK/KCP

REGION V IAE

U. S. Nuclear Regulatory Commission
Region V
Creskside Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director,
Division of Resident,
Reactor Projects and Engineering Programs

Subject: Time Extension for Report - DER 83-60
A 50.55(e) Potentially Reportable Condition Relating To
Wiring In Unit 2 Main Steam And Feedwater Actuation System by
Vitro Does Not Meet IEEE-384 Separation Criteria.
File: 83-019-026; D.4.33.2

Reference: (A) Telephone Conversation between P. Narbut and E. Tucker on
August 30, 1983.
(B) ANPP-27911, dated October 3, 1983 (Interim Report)


Dear Sir:

The NRC was notified of a potentially reportable deficiency in
Reference (A), and an Interim Report was transmitted by Reference (B).
At that time, it was estimated that a Final Report would be available by
November 30, 1983.

Due to the extensive investigation and evaluation required, it is now
expected that this information will be finalized by December 28, 1983, at
which time a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President,
Nuclear Projects Management
ANPP Project Director

EEVBJr/KCP:ru

cc: See Page 2

8401040220 831130
PDR ADOCK 05000529
S PDR

70-2710

Mr. T. W. Bishop
DER 83-60
Page 2

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
G. C. Andognini
J. A. Roedel
D. B. Fasnacht
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. R. Bynum
D. D. Green/P. P. Klute
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli
S. R. Frost
J. Self
D. Canady

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway - Suite 1500
Atlanta, Georgia 30339