

50-528

RECEIVED  
NEC

# Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

November 29, 1983  
ANPP-28314-BSK/KCP

REGION V

U. S. Nuclear Regulatory Commission  
Region V  
Creekside Oaks Office Park  
1450 Maria Lane - Suite 210  
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director,  
Division of Resident,  
Reactor Projects and Engineering Programs

Subject: Time Extension for Report - DER 83-50  
A 50.55(e) Potentially Reportable Condition Relating To  
Reactor Coolant Pump Has Broken Impeller Blade.  
File: 83-019-026; D.4.33.2

Reference: (A) Telephone Conversation between T. Young and R. Tucker on  
July 18, 1983.  
(B) ANPP-27594, dated August 19, 1983 (Interim Report)


Dear Sir:

The NRC was notified of a potentially reportable deficiency in  
Reference (A), and an Interim Report was transmitted by Reference (B).  
At that time, it was estimated that a Final Report would be available by  
November 29, 1983.

Due to the extensive investigation and evaluation required, it is now  
expected that this information will be finalized by January 27, 1984, at  
which time a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,



E. E. Van Brunt, Jr.  
APS Vice President,  
Nuclear Projects Management  
ANPP Project Director

EEVBJr/KCP:ru

cc: See Page 2

8401040266 831129  
PDR ADOCK 05000528  
S PDR

IC27  
11/2

Mr. T. W. Bishop  
DER 83-50  
Page 2

cc: Richard DeYoung, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

T. G. Woods, Jr.  
G. C. Andognini  
J. A. Roedel  
D. B. Fasnacht  
A. C. Rogers  
B. S. Kaplan  
W. E. Ide  
J. Vorees  
J. R. Bynum  
D. D. Green/P. P. Klute  
A. C. Gehr  
W. J. Stubblefield  
W. G. Bingham  
R. L. Patterson  
R. W. Welcher  
R. M. Grant  
D. R. Hawkinson  
L. E. Vorderbrueggen  
G. A. Fiorelli  
S. R. Frost  
J. Self  
D. Canady

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway - Suite 1500  
Atlanta, Georgia 30339