


UPDATE REPORT - PREVIOUS REPORT DATE 09-20-83  
LICENSEE EVENT REPORT

CONTROL BLOCK: 

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

001 M I D C C C 1 2 0 0 1 - 1 0 1 0 1 0 1 0 1 - 1 0 1 0 3 4 1 1 1 1 1 4 5  
7 8 9 14 15 25 26 31 32 33  
CON'T LICENSEE CODE LICENSE NUMBER LICENSE TYPE JJ CMT 33

CCN'T

REPORT  
SOURCE

DESCRIPTION AND PROBABLE CONSEQUENCES

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

012 DURING PERFORMANCE OF THE ECCS FLOW BALANCE BORON INJECTION SYSTEM, IT WAS FOUND THAT  
013 THE WEST CENTRIFUGAL CHARGING PUMP MINIMUM FLOW (TOTAL FLOW) TO THE THREE MOST  
014 CONSERVATIVE BRANCH LINES WAS 317.0 GPM WHICH WAS BELOW THE MINIMUM ALLOWABLE RATE OF  
015 1345.8 GPM. THIS EVENT WAS NON-CONSERVATIVE WITH RESPECT TO TECHNICAL SPECIFICATION  
016 14.5.2.f. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS OCCURRENCE OF A SIMILAR  
017 NATURE INCLUDES: 050-315/82-075.

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE		COMP SUBCODE		VALVE SUBCODE	
S F (11)		E (12)		B (13)		P U I M I P I X I X (14)		B (15)		Z (16)	
EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.		COMPONENT MANUFACTURER	
8 3 (17)		0 1 9 1 0 (18)		0 1 3 (19)		X (20)		1 (21)		P 0 1 2 1 5 (22)	
ACTION TAKEN		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		PRIME COMP. SUPPLIER	
A (13) Z (19)		Z (20)		Z (21)		0 1 0 1 0 1 0 (23)		N (24)		N (25)	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)											

110 THE WEST CENTRIFUGAL CHARGING PUMP WAS REPAIRED BY REPLACING THE ROTATING ASSEMBLY.

111 AN ORIFICE WAS INSTALLED ON DISCHARGE OF EAST PUMP TO OBTAIN SIMILAR FLOWS FROM BOTH

112 CENTRIFUGAL CHARGING PUMPS. THE ECCS FLOW BALANCE TEST WAS COMPLETED WITH ACCEPTABLE

113 RESULTS.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	8	9	10	11	12	13	14	15
H	(30)	0	1	0	1	0	0	B	(31)
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	8	9	10	11	12	13	14	15
Z	(32)	Z	(33)	NA	(34)	NA	(35)	NA	(36)
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	8	9	10	11	12	13	14	15
0	1	0	1	0	1	0	1	Z	(37)
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	8	9	10	11	12	13	14	15
0	1	0	1	0	1	0	1	NA	(38)
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	8	9	10	11	12	13	14	15
Z	(39)	NA	(40)	NA	(41)	NA	(42)	NA	(43)
PUBLICITY		ISSUED		DESCRIPTION					
1	0	8	9	10	11	12	13	14	15
N	(44)	NA	(45)	NA	(46)	NA	(47)	NA	(48)

8401060311 831229  
PDR ADDOCK 05000315  
S PDR

NRC USE ONLY

NAME OF PREPARER J. L. RISCHLING

NRC USE ONLY

(616) Acc