

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0
1
W
I
K
N
P
1
2
0
0
-
0
0
0
0
-
0
0
3
4
1
1
1
1
4
5

CONT

0
1
L
6
0
5
0
0
0
3
0
5
7
1
2
0
1
8
3
8
1
2
3
0
8
3
9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0
2 During full power operation, the 1B containment spray pump breaker failed to close
0
3 when called upon during the monthly pump and valve surveillance test. This placed the
0
4 plant in an LCO per TS 3.3.b.2.B and is reportable per TS 6.9.2.b.(2) as operation in
0
5 a degraded mode permitted by an LCO. Since the 1A containment spray pump had already
0
6 been demonstrated operable, there was no effect on plant operation or public health and
0
7 safety.

0
8

0
9
S
B
11
X
12
Z
13
C
K
T
B
R
K
14
D
15
Z
16

17
8
3
0
3
2
0
3
L
0

X
18
Z
19
Z
20
Z
21
0
0
0
22
N
23
Y
24
A
25
A
1
8
0
26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1
0 The plant electricians visually inspected the pump motor and breaker and found no
1
1 evidence of damage. Operations then started the pump from the Control Room with
1
2 currents, vibrations, and flow readings all acceptable. This appears to be an isolated
1
3 failure; the pump will continue to be monitored as a part of the existing SP and PM
1
4 program. No further action is required.

1
5
E
28
1
0
0
29
NA
30
B
31
Surveillance Test
32

1
6
Z
33
Z
34
NA
35
NA
36

1
7
0
0
0
37
Z
38
NA
39

1
8
0
0
0
40
NA
41

1
9
Z
42
NA
43

2
0
N
44
NA
45

NAME OF PREPARER S.L. Bernhoft/J.G. Thorgersen

PHONE: (414) 388-2560

8401060348 831230
 PDR ADOCK 05000305
 S PDR

DMS

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

December 30, 1983

Mr. J. G. Keppler, Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr. Keppler:

Docket 50-305
Operating License DPR-43
Reportable Occurrence 83-032/03L-0

In accordance with the requirements of the Technical Specifications, Section 6.9, the attached Licensee Event Report for reportable occurrence 83-032/03L-0 is being submitted.

Very truly yours,

A handwritten signature in cursive script, appearing to read "C. W. Giesler".

C. W. Giesler
Vice President - Nuclear Power

JGT/jks

Attach.

cc - Dir, Office of Inspection & Enforcement
US NRC, Washington, DC 20555
Dir, Office of Mgt Info & Program Control
US NRC, Washington, DC 20555
INPO Records Center
Suite 1500, 1100 Circle 75 Parkway
Atlanta, GA 30339
Mr. Robert Nelson, NRC Resident Inspector
RR #1, Box 999, Kewaunee, WI 54216
Mr. S. A. Varga, Chief
US NRC, Washington, DC 20555

1/11/84
3 1984
E22