

## (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	C	A	D	C	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	9					14	15											25	26							30	57	CAT	58
LICENSEE CODE								LICENSE NUMBER												LICENSE TYPE										

CON'T

01 REPORT SOURCE L 05000275 7 11 1783 8 121983 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During initial fuel load, with Diesel Generators (D/G) 1-1 and 1-3 out of service,

0 3 | D/G 1-2 air receiver 1-2a fell below its minimum pressure setpoint. A redundant

0 4 | air receiver was available to start the D/G 1-2 in the event of an emergency.

0 5 | However, the shift foreman declared D/G 1-2 Inoperable and immediately suspended

0 6 | all operations involving core alterations in accordance with Technical

0 7 | Specification Section 3.8.1.2.

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP SUBCODE		VALVE SUBCODE					
0	9	E	E	E	B	V	A	L	V	E	X	F	B				
7	8	9	10	11	12	13	14	15	16	17	18	19	20				
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE				REPORT TYPE		REVISION NO.					
17		8	3	--	0	2	7	/	0	3	L	--	0				
21	22	23	24	25	26	27	28	29	30	31	32						
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
C	Z	Z	Z	Z	0	0	0	Y	0	0	N	A	X	9	9		
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	Diesel generator 1-2 starting air compressor 1-2A internal relief valve would not
1	1	reseal, resulting in its associated air receiver falling below its minimum
1	2	pressure setpoint. All operations involving core alterations were suspended.
1	3	The malfunctioning relief valve was replaced. The air receiver was subsequently
1	4	repressurized and diesel generator 1-2 declared Operable.

FACILITY STATUS				% POWER				OTHER STATUS				METHOD OF DISCOVERY				DISCOVERY DESCRIPTION			
1	5	H	28	0	0	0	29	NA				30	A	31	Operator Observation				32
7	8	9		10	11	12	13					44	45	46				80	

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z (33) Z (34) NA NA

PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION
1 7	0 0 0 (37) Z (38)	NA

PERSONNEL INJURIES  
NUMBER DESCRIPTION (41)

1	8				(40)	
7	9	0	0	0	1.1	1.2

NA  
8401040308 831219

LOSS OF OR DAMAGE TO FACILITY  
TYPE DESCRIPTION (43)

1 9 Z (42)

PDR - ADCK 05000275  
S PDR

PUBLICITY  
ISSUED DESCRIPTION (45) NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20

2 0 N 44

NRC USE ONLY

NAME OF PREPARER William J. Kelly

PHONE 805-595-7351

PACIFIC GAS AND ELECTRIC  
DIABLO CANYON POWER PLANT  
UNIT 1 DOCKET NO. 50-275  
LICENSEE EVENT REPORT 83-027/01T-0

SUPPLEMENTAL INFORMATION

From the perspective that a redundant air receiver was available at all times to start Diesel Generator 1-2 in the event of an emergency, this event would not be reportable. However, the shift foreman declared the D/G Inoperable and satisfied the Action Statements of Technical Specification Section 3.8.1.2. For this reason, PGandE is reporting this event per Technical Specification Section 6.9.1.13b. This event has in no way affected the public's health and safety.

RECEIVED

NRC

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94105 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER  
MANAGER

DEPARTMENT OF NUCLEAR PLANT OPERATIONS  
NUCLEAR POWER GENERATION

REGION V M&E

December 19, 1983

Mr. John B. Martin, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, CA 94596-5368


Re: Docket No. 50-275, OL-DPR-76  
Diablo Canyon Unit 1  
Licensee Event Report 83-027/03L-0  
Inoperable Diesel Generator

Dear Mr. Martin:

Pursuant to Section 6.9.1.13b of the Technical Specifications,  
Appendix A to the Diablo Canyon Unit 1 Operating License, the enclosed  
Licensee Event Report is submitted concerning an Inoperable Diesel Generator.

This event has in no way affected the public's health and safety.

Sincerely,



Enclosure

cc: G. W. Knighton

Director, Office of Management Information  
and Program Control

Service List

1/1 IE 22