

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C M G S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28

CONT

01 REPORT SOURCE L 5 0 5 0 0 0 3 7 0 7 1 1 2 6 8 3 3 1 2 2 2 8 3 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During completion review of periodic tests and other routine tasks on 11/28/83 it
03 was discovered that the 7 day "ice condenser intermediate deck door and monitoring
04 system inspection" surveillance test had not been performed on 11/24-25/83 as
05 scheduled. The doors were subsequently declared inoperable retroactive to 11/26/83
06 (25% grace period expiration date). This failure to perform surveillance as required
07 by T.S.3.6.5.3 (ice condenser doors) is reportable per T.S.6.9.1.1(c). No frost
08 accumulation existed which would have prevented fulfillment of the ice condenser
09 design function. Health and safety of the public were unaffected.

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE SUBCODE SUBCODE
S B 11 X 12 Z 13 X X X X X X 14 2 15 2 16
17 LER/DO REPORT NUMBER 8 13 18 0 8 2 19 0 3 20 L 21 0
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER 26
X 18 2 19 Z 20 Z 21 0 0 0 0 N 23 N 24 L 25 X 9 9 9 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The operator responsible for having the test performed was engaged in a unit
11 startup and was unable to complete the routine task list. Further, he failed to
12 notify others when he was unable to have the test performed. In addition, no one
13 was assigned review responsibility when the periodic test scheduler was off duty.
14 The test was performed satisfactorily on 11/28/83. The shift turnover checklist
15 was revised to require notifications of uncompleted tasks.

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
B 28 0 8 9 29 NA B 31 Periodic Test Review
16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
Z 33 Z 34 NA NA

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
0 0 0 37 Z 38 NA

18 PERSONNEL INJURIES NUMBER DESCRIPTION 41
0 0 0 40 NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
Z 42 NA

20 PUBLICITY ISSUED DESCRIPTION 45
N 44 NA

NAME OF PREPARER Phillip B. Nardoci

PHONE (704) 373-7432

8401040311 831222
PDR ADOCK 05000370
S PDR

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

December 22, 1983

TELEPHONE
(704) 373-4531

93 DEC 29 A 8:58

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street NW, Suite 2900
Atlanta, Georgia 30303

Subject: McGuire Nuclear Station Unit 2
Docket No. 50-370
LER/RO-370/83-82

Dear Mr. O'Reilly:

Please find attached Reportable Occurrence Report RO-370/83-82. This report concerns T.S. 3.6.5.3, "The Ice Condenser Inlet Doors, Intermediate Deck Doors, and Top Deck Doors Shall Be Closed and Operable". This incident was considered to be of no significance with respect to the health and safety of the public.

Very truly yours,

H.B. Tucker / jfw

Hal B. Tucker

PBN:jfw
Attachment

cc: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. W. T. Orders
NRC Resident Inspector
McGuire Nuclear Station

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

OFFICIAL COPY

IE 22

1/0