

OPERATING DATA REPORT

DOCKET NO. 50-286
 DATE 12/01/83
 COMPLETED BY L. Kelly
 TELEPHONE (914) 732-8200

OPERATING STATUS

1. Unit Name: Indian Point No. 3 Nuclear Power Plant
2. Reporting Period: November 1983
3. Licensed Thermal Power (MWt): 3025
4. Nameplate Rating (Gross MWe): 1013
5. Design Electrical Rating (Net MWe): 965
6. Maximum Dependable Capacity (Gross MWe): 1000
7. Maximum Dependable Capacity (Net MWe): 965
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720	8016.0	63,577.0
12. Number Of Hours Reactor Was Critical	0	333.7	34,424.5
13. Reactor Reserve Shutdown Hours	0	0	0
14. Hours Generator On-Line	0	229.1	33,142.0
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	0	282,244	86,425,645
17. Gross Electrical Energy Generated (MWH)	0	68,310	26,366,610
18. Net Electrical Energy Generated (MWH)	0	60,735	25,244,178
19. Unit Service Factor	0	2.9	52.1
20. Unit Availability Factor	0	2.9	52.1
21. Unit Capacity Factor (Using MDC Net)	0	.8	41.2
22. Unit Capacity Factor (Using DER Net)	0	.8	41.2
23. Unit Forced Outage Rate	100	94.6	22.2

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

8401120230 831130
 PDR ADOCK 05000286
 R PDR

25. If Shut Down At End Of Report Period, Estimated Date of Startup: (Est. January 1984)
26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

Forecast	Achieved
_____	_____
_____	_____
_____	_____

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-286
UNIT Indian Point
No. 3
DATE 12/01/83
COMPLETED BY L. Kelly
TELEPHONE (914) 739-8200

MONTH November 1983

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>-</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH November 1983

DOCKET NO. 50-286
 UNIT NAME NO. 3
 DATE 12/01/83
 COMPLETED BY L. Kelly
 TELEPHONE 914-739-8200

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
03	830618	F	720	A	3		N/A	N/A	Electrical malfunction in the main generator.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit F - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

⁵
 Exhibit H - Same Source

SUMMARY OF OPERATING EXPERIENCE

NOVEMBER 1983

Indian Point Unit 3 remains in a forced outage caused by a malfunction in the main electrical generator.

Repairs are now in progress and it is estimated that the unit will be returned to service in January 1984.

MONTHLY I & C CATEGORY I REPORT

November 1983
MONTH

W.R. #	DATE	EQUIPMENT	MALFUNCTION	CORRECTIVE ACTION
1-1960	3-19-83	Thermocouple #1 in Hydrogen Recombiner #32	Improper reading	Replaced thermocouple
1-2200	6-12-83	Gross Failed Fuel Detector Neutron Channel	Improper reading	Replaced discriminator operational amplifier
1-2357	11-26-83	Plant Vent Radiogas monitor R-14	Improper indication	Replaced four GM tubes in detector

MONTHLY MAINTENANCE REPORT

November 1983

MONTH

MWR#	DATE	EQUIPMENT	MALFUNCTION	CORRECTIVE ACTION
I-3995	11-2-83	Service Water Pump #36	Packing leaks	Replaced packing
I-3900	11-23-83	Instrument Air Regulator for Dessicant Dryer	Electrical short in fuse holder	Replaced fuse block and ring terminals
I-3162	11-29-83	Exhaust Fan 314 for Diesel Generator #31	Fan does not operate	Repaired control wiring
I-3933	11-29-83	Steam Generator Blowdown Valve PCV-1215	Valve does not stroke	Cleaned and readjusted valve packing

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 739.8200



December 12, 1983
IP-LK-3565


Docket No. 50-286
License No. DPR-64

Director, Nuclear Reactor Regulation
Office of Management Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Sir:

Enclosed you will find two copies of the monthly operating report relating to Indian Point 3 Nuclear Power Plant for the month of November, 1983.

Very truly yours,


John C. Brons
Resident Manager

LK/bam
Enclosure

cc: Director, Office of Inspection & Enforcement (40 Copies)
c/o Distribution Services Branch, DDC, ADM
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. Thomas E. Murley, Regional Administrator
Region 1
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

IP3 Resident Inspectors' Office
George Wilverding (SRC), WPO
J. P. Bayne, WPO
S. V. Fuller, NYO
W. R. Yario, NYO

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

IE24
1/1