NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | LICENSEE CODE: M I D C C 2 (2) | LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) | LICENSE TYPE: 4 1 1 1 1 (4) | CAT: (5)

CON'T 01 | REPORT SOURCE: L (6) | DOCKET NUMBER: 0 5 0 0 0 3 1 6 (7) | EVENT DATE: 1 2 0 6 8 3 (8) | REPORT DATE: 1 2 2 9 8 3 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 DURING NORMAL OPERATION WHILE PERFORMING A ROUTINE TOUR, AN AUXILIARY EQUIPMENT
03 OPERATOR DISCOVERED THAT THE RECORDER (2-CS-001) USED FOR CONTAINMENT SUMP FLOW
04 MONITORING, CHART PAPER WAS NOT ADVANCING. THIS IS NON-CONSERVATIVE WITH RESPECT
05 TO TECHNICAL SPECIFICATION 3.4.6.1b. THE ACTION REQUIREMENTS WERE MET. PUBLIC
06 HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS OCCURRENCES OF A SIMILAR NATURE
07 INCLUDE 315/83-061, 058, AND 044, AND 316/82-019 AND 83-086.
08

09 | SYSTEM CODE: I E (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: E (13) | COMPONENT CODE: I N S T R U (14) | COMP. SUBCODE: R (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR: 8 3 | — | SEQUENTIAL REPORT NO.: 1 2 0 | / | OCCURRENCE CODE: 0 3 | REPORT TYPE: L | — | REVISION NO.: 0

ACTION TAKEN: E (18) | FUTURE ACTION: Z (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: N (25) | COMPONENT MANUFACTURER: E 3 3 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE OPERATOR ON TOUR REPORTED PROBLEMS WITH THE TAKE UP REEL. THE CONTROL AND
11 INSTRUMENTATION SECTION REPAIRED THE RECORDER. A DESIGN CHANGE HAS BEEN SUBMITTED
12 TO PROVIDE A MORE RELIABLE RECORD OF SUMP FLOWS.
13
14

15 | FACILITY STATUS: E (28) | % POWER: 1 0 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): OPERATOR OBSERVATION

16 | ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES
17 | NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

PERSONNEL INJURIES
18 | NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 | TYPE: Z (42) | DESCRIPTION: NA

PUBLICITY
20 | ISSUED: N (44) | DESCRIPTION (45): NA | NRC USE ONLY

8401060435 831229
PDR ADOCK 05000316
S PDR

NAME OF PREPARER D. F. KRAUSE

PHONE (616) 465-5901

GPO 917-226