

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

RECEIVED
NRC

1983 DEC 29 AM 11:14

December 19, 1983
ANPP-28462-BSK/KCP

REGISTRY FILE

U. S. Nuclear Regulatory Commission
Region V
Creekside Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs

Subject: Interim Report - DER 83-80
A 50.55(e) Potentially Reportable Deficiency: Main Feedwater
Isolation Valves (Anchor/Darling) Closed In 20 Seconds.
Specification 13-MM-234A Specifies A 5 Second Closure Time.
File: 83-019-026; D.4.33.2


Reference: Telephone Conversation between P. Narbut and K. C. Parrish on
November 22, 1983.

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the
referenced telephone conversation. At that time, it was estimated that a
determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an Interim
Report is attached. It is now expected that this information will be
finalized by February 17, 1984, at which time a complete report will be
submitted.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President,
Nuclear Projects Management
ANPP Project Director

8401120302 831219
PDR ADOCK 05000528
S PDR

EEVB/KCP:ru

Attachment

cc: See Page Two

EE17
11/

Mr. T. W. Bishop
DER 83-80
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
G. C. Andognini
J. A. Roedel
L. B. Fasnacht
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. R. Bynum
D. D. Green
P. P. Klute
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli
S. R. Frost
J. Self
D. Canady

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339

INTERIM REPORT - DER 83-80
POTENTIAL REPORTABLE DEFICIENCY
ARIZONA PUBLIC SERVICE COMPANY (APS)
PVNGS UNITS 1, 2, & 3

I. Potential Problem

Specification 13-MM-234A, requires that the Main Feedwater Isolation Valves (MFIV) shall close fully within 5 seconds after receipt of a signal. During Startup testing it was determined that the Anchor Darling valves supplied to PVNGS were designed to close within 20 seconds. The valves are identified by the following tag numbers:

1JSGA-UV-174	2JSGA-UV-177	3JSGA-UV-174
1JSGA-UV-177	2JSGA-UV-177	3JSGA-UV-177
1JSGB-UV-132	2JSGB-UV-132	3JSGB-UV-132
1JSGB-UV-137	2JSGB-UV-137	3JSGB-UV-137

II. Approach To and Status of Proposed Resolution

Bechtel engineering is corresponding with Anchor Darling to determine reportability and technical justification for corrective action.

III. Projected Completion of Corrective Action and Submittal of the Final Report

Evaluation of this condition and submittal of the Final Report is Forecast to be completed by February 17, 1984.