

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MIDIC 2 2 01010101010101010101 3 411111 4 CAT 53

CON'T

REPORT SOURCE L 6 0 1 5 1 0 1 0 1 3 1 1 6 7 1 1 1 2 8 8 3 5 1 1 2 1 2 1 1 8 1 3 9  
60 61 DOCKET NUMBER 66 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

012 THE LOWER CONTAINMENT OUTER PERSONNEL AIR LOCK DOOR EXCEEDED THE SEAL LEAKAGE LIMITS  
013 DURING THREE CONSECUTIVE TESTS (11-28-83, 11-30-83 AND 12-2-83). ON EACH OCCASION THE  
014 SEAL WAS INSPECTED, CLEANED AND THE DOOR WAS RETESTED SATISFACTORILY. AS A PRE-  
015 CAUTIONARY MEASURE, THE DOOR WAS REMOVED FROM SERVICE ON 12-3-83 FOR OUTER DOOR SEALS  
016 REPLACEMENT. THESE EVENTS WERE NON-CONSERVATIVE WITH RESPECT TO TECHNICAL SPECIFICA-  
017 TION 3.6.1.3. THE ACTION REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT  
018 AFFECTED. SIMILAR OCCURRENCES: 315/78-023, 037, 043, 82-005, 83-017 AND 316/78-082.

SYSTEM CODE S I D 11		CAUSE CODE E 12		CAUSE SUBCODE B 13		COMPONENT CODE P I E I N I E T I R 14		COMP SUBCODE A 15		VALVE SUBCODE Z 16	
LER/RO REPORT NUMBER 18 13		EVENT YEAR 23		SEQUENTIAL REPORT NO. 1 1 6		OCCURRENCE CODE 0 1 3		REPORT TYPE L		REVISION NO. 0	
ACTION TAKEN F 13		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 1 0 1 0 1		ATTACHMENT SUBMITTED N 23	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27		NPRO-4 FORM SUB. N 24		PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER W 3 1 0 1 2					

110 THE OUTER DOOR SEALS WERE REPLACED, ADJUSTMENTS WERE MADE TO THE TOP, LEFT AND RIGHT

111 CLAMPS OF THE OUTER DOOR FRAME AS REQUIRED TO ENSURE A PROPER SEAL. THE DOOR WAS

112 RETESTED SATISFACTORILY. SINCE THE REPLACEMENT OF THE OUTER DOOR SEALS AND CLAMP

113 ADJUSTMENTS THE DOOR HAS SUCCESSFULLY PASSED SEVEN CONSECUTIVE NORMAL SCHEDULED TESTS.

FACILITY STATUS		POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	1	0	0	NA	B		SURVEILLANCE TEST	
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	Z	NA	NA				
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	0	Z	NA			
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0		NA			
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z		NA					
PUBLICITY		ISSUED		DESCRIPTION					
2	0	N		NA					

8401040367 831221  
PDR ADOCK 05000316  
S PDR

NRC USE ONLY

NAME OF PREPARER R. A. PALMER

(616)465-5901

NRC USE ONLY