



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

84 JAN 4 AM 10
December 30, 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-096/1 -
Update Report - Fire Door
OC313 Inoperable
AECM-83/0812


This is an update to a previous report submitted October 26, 1983, for the event described below. The purpose of this update is to provide a revised estimated completion date.

On September 26, 1983, fire door OC313, which is the double door to the main entrance of the lobby in the Control Building, was reported to be inoperable. The door had been damaged as a result of heavy use and would no longer secure. In accordance with Technical Specification 3.7.7.a, a fire watch was established. Because the door could not be returned to an operable status within seven days, the details concerning this event are being submitted as a Special Report pursuant to Technical Specification 6.9.2.

The parts necessary to repair the door are presently on order and the repairs are now expected to be complete by February 28, 1984. The fire watch will be maintained until the door is restored to an operable status. This condition has no effect on the health and safety of the public and does not constitute a threat to plant safety.

Yours truly,

8401060477 831230
PDR ADOCK 05000416
S PDR


L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap

cc: (See Next Page)

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0812

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555